



Project Group I
Power Sector, Project Engineering Management
Bharat Heavy Electricals Limited
NOIDA

Project	250 MW RVUNL Chhabra TPS Unit-4 - ESP Restoration project
Package	Misc Cabling Erection Items- Cable Lugs
Enquiry Ref.	PE/PG/CU4/E-6974/2022 dtd. 13.05.2022
Dated	21.05.2022
Subject	Clarification w.r.t. BOQ items

Please note the following:

“For Items at Sr. No. 2 to 10 of tender BOQ, Cable lugs of PIN type 0.5 sq. mm is required but if the bidder cannot provide the same then 0.75 sq. mm PIN Type can also be considered.”

Above is for information please.

Please ensure submission of bids on or before due date.

Thanking You.

For and on behalf of BHEL

Niyati Aggarwal
(Manager/PG-I/BHEL-PEM)
niyati@bhel.in
Ph. No. +91-120-4368726
9910664864