

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
पावर सेक्टर- पश्चिमी क्षेत्र
श्रीमोहिनी कॉम्प्लेक्स, 345 - किंग्सवे
नागपुर- 440 001



Bharat Heavy Electricals Limited
Power Sector-Western Region
Shreemohini complex, 345 - Kingsway
Nagpur-440 001

फोन / Phone 0712- 3048600 TO 604 फैक्स FAX: 0712- 3048698- 699/ 3048605 www.bhelpswr.co.in

FAX (PCC by Courier/Speedpost

Ref: BHE/PW/PUR/SKT - CHIMNEY/664/CLA-01

DT : 01/08/2009

TO,

ALL BIDDERS

Dear Sir,

SUB: CLARIFICATIONS ON TENDER SPECIFICATION-01

NAME OF THE WORK: CONSTRUCTION OF TWIN FLUE RCC CHIMNEY OF HEIGHT 220M WITH BRICK LINERS USING SLIPFORM SHUTTERING EQUIPMENT ETC COMPLETE AT **2X250 MW SIKKA THERMAL POWER STATION**, GUJARAT STATE ELECTRICITY CORPORATION LIMITED, DISTT JAMNAGAR GUJARAT

REF: SPECIFICATION NO. BHE/PW/PUR/SKT - CHIMNEY/664.

For subject tender, some bidders have raised queries which are clarified as below.

1) Que : Inner & Outer dia of Shell of Chimney ?

Ans : Outer Dia at Bottom – 24.4M (Approx) & Outer Dia at Top – 16.0M (Approx).

2) Que ; Standards for details of Structural Members?

Ans : As per Indian Standards all connection details shall be prepared.

3) Que : Fixing Details of GI Strakes?

Ans : No strakes will be provided. Also there is no such clause in Design Memorandum.

4) Sand Blasting & Painting Specification ?

Ans : As per spec PE-TS-226-620-C001 VOL-II, Sheet 167 of 292 cl 3.04.04

5) Soil Bore Log data in Chimney ?

Ans : Soil Bore Log data attached with this clarification.

Above clarification shall be part of tender specification. Bidders are requested to submit this clarification duly signed & stamped along with their offer as a part of technical bid. All other terms and condition shall remain unchanged.

Thanking you,

SENIOR MANAGER (PURCHASE)