

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
पावर सेक्टर- पश्चिमी क्षेत्र
श्रीमोहिनी काम्पलेक्स, 345 - किंग्सवे
नागपुर- 440 001



Bharat Heavy Electricals Limited
Power Sector-Western Region
Shreemohini complex, 345 - Kingsway
Nagpur-440 001

फोन / Phone 0712- 3048600 TO 604 फैक्स FAX: 0712- 3048698- 699/ 3048605 www.bhelpswr.co.in

Ref: BHE/PW/PUR/MAUDT-CRH/OJ-149

Date 19/12/2009

Sub: Clarification-01, for HLHR Crane for NTPC Mauda, Vindhyachal Rihand and Chandrapur

-----Page 1 of 1-----

To

ALL BIDDERS

JOB: SERVICES OF HLHR CRAWLER CRANE ON MONTHLY LEASING BASIS FOR CONSTRUCTION WORK IN MAUDA SUPER THERMAL POWER STATION NTPC LIMITED TEHSIL-MAUDA, DIST-NAGPUR MAHARASHTRA.

Tender Specification No: BHE/PW/PUR/MAUDT-CRH/OJ-149

Our clarification of queries is as under

=====

1) Clause 1.1, sub clause 7/8- Crawler to crawler outer dimension (SCC of NIT),

Query-The crawler to Crawler outer dimension of the HLHR crane required at Mauda site & Vindhyachal site is maximum 10.5.meter. We request you to please revise the crawler outer dimension to atleast 15 meter (as mentioned in the Specs. of HLHR cranes at Chandrapur site & Rihand site) so that suitable cranes can be offered.

Answer- The main job to be performed by HLHR is the critical lifts i.e. ceiling girders to its destinations. The ceiling Girders are fabricated / assembled at place as per site space availability looking to the convenience of shifting and lifting to final position. In variably space is required for material like RBs, MBS are required to be fed with the help of other cranes, for which sufficient space is required after placement of the HLHR crane. The space available in boiler cavity is required to be used for carrying out ceiling girder shifting & lifting to final position. The maximum space can be occupied by HLHR crane shall be 13 meter, i.e crawler to crawler width of maximum 13 meter is acceptable.

2) Boom & Jib Combination

Query- The boom + Jib combination for above projects are different from each other. We suggest that the maximum height be specified in tender is to be met with a combination of Main boom + jib (instead of specifying the Jib length) Copy of PSER tender specs is attached for your guidance. This will allow more cranes / vendors to participate.

Answer- The boom + jib combination shall be suitable for lifting the critical lift i. e. ceiling girders by main boom + jib combination. The luffing jib length shall be capable of lifting the equipment/ structure of maximum 20 MT. Maximum top of eqpt/ structure will be at 97 meter height. The Main boom + jib combination shall be minimum 120 mtr to maximum of 130 meter.

FOR BETTER UNDERSTANDING THE WORK REQUIREMENT AND SITE SPECIFIC CONDITIONS IT IS REQUESTED TO VISIT RESPECTIVE SITE FOR QUOTING THE CRANE TYPE & MODEL.

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Clarification-01" against NIT-7628 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,
Yours faithfully,

Sr DGM (Purchase)