

भारत हेवी इलेक्ट्रिकल्स लिमिटेड

पावर सेक्टर – पच्छिम क्षेत्र
श्रीमोहिनी कॉम्प्लेक्स, 345 – किंग्सवे
नागपुर – 440 001

फॅक्स / FAX: 0712 – 3048605



Bharat Heavy Electricals Limited

Power Sector – Western Region
Shreemohini Complex, 345 – Kingsway
Nagpur – 440 001

वेब साईट / WEB SITE: www.bhelpswr.co.in

Ref: BHE / PW / PUR / NST- ENB / 713/CAL-01

DT: 17/03/2010

TO,

ALL BIDDERS

Dear Sir,

SUB : CLARIFICATION – 01

NAME OF WORK: CONSTRUCTION OF CLOSED SHED WITH STORE OFFICE AND C&I STORE ROOM, CLOSED SHED, STRUCTURAL SEMI CLOSED SHED, AREA DEVELOPMENT FOR PORTA CABIN, DEVELOPMENT OF OPEN STORAGE YARD, ROADS, FENCING, DRAINAGE, INCLUDING INTERNAL / EXTERNAL ELECTRIFICATION OF OFFICE/STORES & OPEN STORAGE YARD AREAS, APPROACH ROAD FROM OPEN YARD TO PLANT AREA AND RAISED CONCRETE PLATFORM ETC. AT 5X270 MW INDIABULLS NASIK TPP ELENA POWER & INFRASTRUCTURE LIMITED DISTT. – NASIK MAHARASHTRA.

TENDER SPECIFICATION No: BHE / PW / PUR / NST- ENB / 713

Some of the bidders has asked clarifications Following clarifications for the above tender shall be part of tender specification.

- 1) QUE by Bidder- Refer Section- H of Price Bid for External Illumination – item no-3 & 4 is for supply & installation of weather proof flood light of 400 watt-24 Nos, to be mounted on 410 SP.28 POLES. However there is no provision of supply of poles for this item. Item no-2 is for supply of above pole-59 nos for 150 watt sodium vapour lamps under item no-1

Clarification by BHEL- Whether poof flood light illuminaries-24 nos kept under sr. no-3 of Section-H shall be installed over the pole under sr no-2 of section-H. Out of 59 poles under sr. no-2 , 24 no poles shall have 2 luminaries (150 as well as 400watts) as per the site requirement. Location of such poles shall be decided as per site condition.

Refer Sr. No- 4 Section-H shall be read as " Installation and commissioning of flood light luminaries, control gear box, cabling & termination for item no-3 on the pole type 410, sp-28 supplied under sr. no-2.

- 2) QUE by Bidder- Refer Section A, C & E item no-10A, 10 & 10 A respectively- These items are for "Supply , fabrication & erection of Tubular truss. Under description of work the wordings are Supply , fabrication & erection as per BHEL drawings with AC Sheet. The wording should " fixing AC sheet" since there is separate item for supply of AC Sheet

Clarification by BHEL : Agreed. Supply & fixing of AC sheet is covered in another items of rate schedule.

भारत हेवी इलेक्ट्रिकल्स लिमिटेड

पावर सेक्टर – पच्छिम क्षेत्र
श्रीमोहिनी कॉम्प्लेक्स, 345 – किंग्सवे
नागपुर – 440 001

फॅक्स / FAX: 0712 – 3048605



Bharat Heavy Electricals Limited

Power Sector – Western Region
Shreemohini Complex, 345 – Kingsway
Nagpur – 440 001

वेब साईट / WEB SITE: www.bhelpswr.co.in

Ref: BHE / PW / PUR / AMRT- ENB / 712/CAL-01

DT: 17/03/2010

The above clarification shall be a part of this tender specification. As such bidders are requested to submit the offer considering the above clarification.

Bidders may please download these documents from web and enclose print out of same with technical bid duly counter signed by your authorized signatory and stamped with official seal as a token of your unqualified acceptance of this clarification.

All other terms & condition of the tender specification shall remain unchanged unless and otherwise expressly amended by BHEL.

Thanking you.

Yours faithfully

SR. MANAGER (PURCHASE)

Thanking you,

Yours faithfully,

SENIOR MANAGER (PUR)