



**BHARAT HEAVY ELECTRICALS LIMITED**  
**PROJECT ENGINEERING MANAGEMENT, NOIDA**

Date-27-Aug-21

**CORRIGENDUM- 01**

<b>PROJECTs</b>	<b>:</b>	<b>Tuticorin FGD</b>
<b>PACKAGE</b>	<b>:</b>	<b>Compressed Air System</b>
<b>ENQUIRY NO</b>	<b>:</b>	PE/PG/NTF/E-6748/21
<b>SUBJECT</b>	<b>:</b>	<b>PRE- BID CLARIFICATION</b>

Type of Corrigendum			
Technical Corrigendum -	<input checked="" type="checkbox"/>	Commercial Corrigendum -	<input type="checkbox"/>

Bidders are requested to go through the following –

**Design condition for equipment selection-** The compressors capacity will be designed in line with Meteorological data Cl. 7.01.00/Vol. II-B, Section B of technical specification( project information with wind and seismic design criteria).

Ambient temperature- 36.5 deg. C DBT,

Relative Humidity – 82% RH at atmospheric pressure at site

Altitude - 1.46 M above MSL

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Gaurav Garg  
Dy. Manager/BOP