



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT

PROJECT : 1X800MW TANGEDCO NORTH CHENNAI TPP **DATE:** - 29.12.2017
PACKAGE : AIR CONDITIONING SYSTEM
TENDER ENQUIRY NO.: PE/PG/NC3/E-5784/2017 dtd. 28.11.2017

Corrigendum-03

1. Reply of Pre-bid queries are enclosed herewith.

All other terms and conditions remain unchanged. You are requested to submit your offer accordingly.

For and on behalf of BHEL

UPENDRA CHAUDHARY
(DY.MGR/BOP Ordering/BHEL-PEM)



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT

Reply of pre-bid queries are as follows:

SI No.	Document Name	Clause No.	As per PRICE FORMAT REV 01	Bidder Query	BHEL Reply
1	Technical Specification As per corrigendum 02 : Annexure 1 : SI No : C2 FRP Cooling Tower capacity amended as minimum 650 TR	BOQ : C) 2.0	Fibreglass reinforced plastic (FRP) cooling towers of adequate capacity, complete with fan, motor, FRP basin, & all accessories as specified (Minimum 450 TR)	Kindly let us know the exact capacity to be consider for our estimate purpose.	Min. capacity of cooling tower for Service building shall be 650 TR