

**Project Engineering
Management**

Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)



Ref No.: GEM/2024/B/4885956/CORRIGENDA/02

Date: 09.05.2024

CORRIGENDUM -02

PROJECT: 2X800 MW MEL SINGRAULI TPP

PACKAGE: COAL BUNKER DEBLOCKING DEVICES-AIR BLASTERS

Bid Number: GEM/2024/B/4885956 dated 24.04.2024

Please note the following:

- **Due Date has been extended from 10.05.2024 to 16.05.2024 till 04:00 PM. Bid Opening shall be done at 04:30 PM on the due date.**
- **Technical Pre-bid queries**

All the other terms and conditions of the tender enquiry shall remain unchanged. All the bidders are requested to quote accordingly.

Thanking You,

With Regards,

For & on behalf of BHEL

Rajeev Kumar
Manager/PG-II-1



2x800 MW MEL SINGRAULI TPP
COAL BUNKER DEBLOCKING DEVICES
(AIR BLASTERS)

SPECIFICATION NO.: PE-TS-504-161-A001

SECTION: III

SUB SECTION: IIIC

REV: 00

DATE: April 2024

Page: 1 of 1

PRE-BID CLARIFICATION

S. No.	Bidder's query	Page No.	BHEL's clarification
1	Equipment drg	Refer Page-13 of 230	FLOW SCHEME FOR COAL BUNKER DEBLOCKING DEVICES (DRG NO PE-DG-504-161-A100)
2	No of equipment	Refer Page-8 of 230	There are 2 units with eight (8) bunkers in each unit. So, total 16 bunkers in complete station. In each unit, there are two (2) bays of four (4) bunkers each.
3	Required no of Air Blasters/equipment	Refer Page-8 of 230	Minimum 6 nos. air blasters per bunker. Actual number shall be based on vendor's proven design based on hopper profile, bulk density of material etc.
4	Capacity of Air Blaster	Refer Page-8 of 230	As per vendor's proven practice depending on hopper profile, bulk density of material etc.
5	Air source- Compressor with its capacity	Refer Page-5 of 230	1 no. tapping of service air with pressure 5-7 Kg/cm ² at feeder floor (EL +22.75m) with 25NB isolation valve shall be provided. Approx. 10 Nm ³ /min (5 Nm ³ /min per unit). Actual requirement may be confirmed by bidder.
6	Air Receiver with capacity		There is no air-receiver dedicated to Air Blasters.
7	Air Drier with its capacity		There is no air-dryer. Bidder to provide FRL assembly as per specification requirement.