



To
ALL BIDDERS,

Sub: Corrigendum 01: ISSUANCE OF CLARIFICATIONS

JOB: FRAMEWORK AGREEMENT (RATE CONTRACT) FOR DEPLOYMENT OF INDUCTION HEATING MACHINE ALONG WITH OPERATORS AT VARIOUS OVERHAULING SITES OF PSWR (MADHYA PRADESH, CHHATISGARH, MAHARASHTRA, GOA & GUJARAT)..

Reference:

1) E-Tender Specification Number: E-Tender Specification No: **BHE/PW/PUR/RC-IHM/2728**

Bidders to kindly take note of the following:

=====

AA) ISSUANCE OF CLARIFICATIONS:

Sl. No	Reference Document	Reference Chapter/Annexure	Reference Tender Clause	Query/Clarification Required	BHEL Reply
1			Scope of work is mentions "Deployment of Induction Heating Machine along with operators & electricians for loosening & tightening of Studs during TG Overhauling".	Our Technicians do not hold any electrical license. If Power supply is provided by the plant electrician to the input of the circuit breaker, which will be placed close to the turbine,, our technicians will draw the supply from the output of the breaker to the machine and transformer.	Accepted
2				POWER SUPPLY- Minimum supply of 415 volt at 150 amps (3 phase 4 wire with neutral) for each m/c. (Electrical wire with proper connections from the power source to our equipment with circuit breaker close to the equipment should be provided by you at site.)	3 Phase Power supply will be made available at the nearest possible point. However, cable lying from junction box to the equipment will be in the scope of the bidder.
3				WATER SUPPLY Minimum 40 PSI at 8 to 10 GPM. Water flow should be continuous with no suspended particles in it.	Asked Input may vary as per plant condition due to layout/aging. Agency shall suitably arrange machines accordingly to meet plant/site requirement.
4				Minimum diameter of the heater rod that we can provide is 12mm. Studs having bore diameter less than 12mm or no inner bore will not be heated by us. Bore length must be minimum 200 mm.	Accepted

5		Page 45 of the NIT Vol 1 point 28	"Advance intimation of 03 days shall be given by BHEL to the Contractor for mobilization of site along with operator & T&P"	Request you to provide 5 to 7 days advance intimation	Advance intimation of 05 days shall be given by BHEL to the Contractor for mobilization of site along with operator & T&P
---	--	-----------------------------------	---	--	---

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing. Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly Digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL → <https://eprocurebhel.co.in>

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,
Yours faithfully,

GM (Purchase)