

To
ALL BIDDERS,

Sub: Corrigendum 02: ISSUANCE OF CLARIFICATIONS

JOB: FRAMEWORK AGREEMENT (RATE CONTRACT) FOR DEPLOYMENT OF INDUCTION HEATING MACHINE ALONG WITH OPERATORS AT VARIOUS OVERHAULING SITES OF PSWR (MADHYA PRADESH, CHHATISGARH, MAHARASHTRA, GOA & GUJARAT)..

Reference:

1) E-Tender Specification Number: E-Tender Specification No: **BHE/PW/PUR/RC-IHM/2728**

Bidders to kindly take note of the following:

AA) ISSUANCE OF CLARIFICATIONS:

Sl. No	Reference Document	Reference Chapter/Annexure	Reference Clause	Tender	Query/Clarification Required	BHEL Reply
1					<i>Sir, we carry 3 phase cables of maximum 15 feet length. We get the supply within this proximity at all plants as the supply is made available to us close to the turbine deck. Request you for the same.</i>	Phase Power supply will be made available at the nearest possible point. However, cable lying from junction box to the equipment should be of suitable length (At least 20 mts).
2	TCC	Chapter-III	Scope of work under Special Condition of Contract		<i>Sir, please note we though heat the studs but only nuts are loosened and tightened by us and not the studs.</i>	Deployment of Induction Heating Machine along with operators & electricians for heating of studs for loosening & tightening of nuts during TG Overhauling.

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
(सार्वजनिक क्षेत्र का उपक्रम)
Bharat Heavy Electricals Limited
(A Public Sector Undertaking)



पावर सेक्टर- पश्चिमी क्षेत्र Power Sector-Western Region
श्रीमोहिनी कॉम्प्लेक्स, 345 किंग्सवे, नागपुर Shreemohini complex, 345 Kingsway Nagpur - 440 001
फोन / Phone 0712- 2858600, फैक्स FAX: 0712-2858699 www.bhelpswr.co.in

BHEL PAN: AAACB4146P

Ref: BHE/PW/PUR/RC-IHM/2728/Corg-02

Date: 24-07-2023

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing. Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly Digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL → <https://eprocurebhel.co.in>

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,
Yours faithfully,

GM (Purchase)