



Ref: PE/PG/MG1/E-4956/2015/CORRIGENDUM/02

Date: 05/08/2015

DUE DATE
14/08/2015
10:00 AM (IST)

Our Ref:

- (i) Enq. No:- PE/PG/MG1/E-4956/2015 dated 15.07.2015
(ii) PE/PG/MG1/E-4956/2015/CORRIGENDUM/01 dated 03.08.2015

Subject: Tender Clarifications & Bid submission due date extension

Bidders have to note the following clarifications with reference to subject tender enquiry:-

- 1.) Bidders have to submit the required credentials/documents/certificates as per Financial PQR document & Revised Technical PQR document enclosed along-with corrigendum No. 01 dated 03.08.2015 to this tender.
- 2.) Base date for PVC is July'15 for the subject tender, as per NIT terms. Bidders have to quote accordingly.
- 3.) Bidders are clarified that for single core cable, inner sheath is not required for the tender.
- 4.) Bidders have to note that SCC for the project has been revised and current SCC (Rev. 02) for 4x270 MW Bhadradi TPS is enclosed along with this corrigendum.
- 5.) The due date of submission of tender is extended from existing date 05/08/2015, 10:00 AM (IST) to 14/08/2015, 10:00 AM (IST). Part-I bids shall be opened on 14/08/2015, 11:00 AM (IST).

Bidders have to submit their offers inline to above clarifications.

Thanking You,

For & on behalf of BHEL

Dheeraj Singh

Sr. Engineer | PG II-2, BHEL PEM | Noida

E-MAIL: dheerajsingh@bhelpem.co.in Ph. No. +91-120-4368864

कृपया प्रेषित करे : Please reply to : फ़ोन Phone No:
बीएचईएल, पीएस-पीईएम BHEL, PS-PEM, 91-120 - 436 8864
पीपीईआई भवन PPEI Building,
प्लॉट नं २५, सेक्टर १६ ए Plot No.25, Sector 16A,
नोएडा - २०१ ३०१ उ प्र Noida-201301 (U.P.)
भारत INDIA

पंजीकृत कार्यालय Registered Office :
बीएचईएल हाउस BHEL House,
सीरी फोर्ट Siri Fort,
नयी दिल्ली - ११० ०४९ New Delhi-110049
भारत INDIA