



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-17-Jan-20

CORRIGENDUM- 03

PROJECT	:	1x 660 MW PANKI TPS
PACKAGE	:	DC LEAD ACID /Ni-Cd BATTERIES
ENQUIRY NO	:	PE/PG/PKI/E-6343/19, Dt:- 11.12.19
SUBJECT	:	Due date extension and Amendment to Technical Specification

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☒

In reference to the above mentioned tender enquiry for **DC LEAD ACID /Ni-Cd BATTERIES** package

Please note the following.


1. Due date has extended from 17-Jan-20 to 27-Jan-20 till 02:00 PM. Bid opening shall be done at 03:00 PM on the due date.
2. Please find the attached amendment to Technical Specification.
3. All bidders to note that all term & conditions of GCC Rev 06 and corrigenda to GCC Rev 06 shall be replaced with GCC rev 07 and accordingly subject NIT shall be considered in compliance with GCC Rev 07. Link for downloading GCC Rev 07 shall be as below:-

<https://www.bhelpem.com/Documents/GCC/GCCRev07.pdf>

GCC Rev 07 is also available at <https://bhel.abcprocure.com>

Yours faithfully,

For and on behalf of BHEL

 (17/1/20)

Rahul Bhatnagar

Dy. Manager



AMENDMENT TO TECHNICAL SPECIFICATION FOR 220V DC BATTERY FOR
1 X 660 MW PANKI THERMAL POWER EXTN PROJECT

SPECIFICATION NO.: PE-TS-426-508-E001

AMENDMENT NO # 1

REV. NO. 00

DATE: 14/01/2020

Page 1 of 1

MODIFIED CLAUSES AS BELOW.

Sl no.	Vol. No.	Section/ Description	Clause no	Page no	Existing clause/details	Modified Clause
1	II	SECTION-II/ (DATASHEET-A)	13	PAGE NO 1 OF 1	Minimum AH rating of battery	Refer attached Annexure-II for battery sizing. * For RWPH and Intake PH & FOPH battery, minimum AH rating shall be 50AH. If battery AH as per load cycle for RWPH and Intake PH & FOPH is below 50AH, bidder has to quote minimum 50AH battery each for RWPH and Intake PH & FOPH.

Shree Kumar
14/01/2020

Hojawane
14.01.2020

S. Sankar Das
14/1/2020