

TENDER ENQUIRY FOR COLTCS OF 2X800 MW TANGEDCO UPPUR - BTG

Reference no: PE/PG/UPP/E-5715/2017-03

Date: 11.10.2017

CORRIGENDA-3


Tender Enquiry no.: PE/PG/UPP/E-5715/2017 Dt: 21.09.2017

DUE DATE
13-OCT-2017
02:00 PM IST

It may please be noted that **Amendment-1 against technical specification for PE-TS-422/423/425-165-N002** for tender enquiry no. **PE/PG/UPP/E-5715/2017 Dt: 21.09.2017** floated for "COLTCS" package for subject project has been issued and hosted.

All bidders are requested to visit BHEL website www.bhel.com (Tender Notification Section) or www.bhelpem.com (https://www.bhelpem.com/Current_Tender.aspx) , all future corrigendum, addendums, amendments, if any, for this tender shall be hosted only on above websites.

With Regards,
For & on behalf of BHEL



(Ramendra K Mech)
Sr. Engr./PG-II/ BHEL-PEM

Please reply to:

Ramendra K Mech, Sr. Engr.
PG-II

Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM, Noida-201301 (U.P.)
Tel No. 0120-4213645/4368519, Fax: 0120-4329106

**SEPC 1X525 MW TUTICORIN TPS STAGE-IV
TANGEDCO 1X800 MW NORTH CHENNAI TPP STG-III
TANGEDCO 2X800 MW UPPUR STPP UNIT#1&2**

AMENDMENT NO. 1

**TECHNICAL SPECIFICATION
FOR
CONDENSER ON LOAD TUBE CLEANING SYSTEMS (COLTCS)**

Specification No. : PE-TS-422/423/425-165-N002 (REV. 0)



**BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
PPEI BUILDING, SECTOR 16 A
NOIDA - 201301**



**TECHNICAL SPECIFICATION FOR
COLTCS**

SPECN. NO.: PE-TS-422/423/425-165-N002

AMENDMENT NO. 1

REV. NO.

0

DATE:

11.10.17

- 1.0 With reference to **Cl. No. 1.4, Point no. 3 of Datasheet A, Section-ID, (page No. 92 to 196 of pdf file) of Technical Specification for 1X800 MW North Chennai & 2X800 MW Uppur projects**, please consider the Specification amended as below:

S. No	Clauses as mentioned in Technical Specification	Amended Clauses
1	Flap of butterfly valve shall be extended to 1300-1400 mm inside the Ball separator.	Flap of butterfly valve shall be extended to 1100 mm inside the Ball separator.

All other specification requirements for COLTCS (except for above), as specified in specification no. PE-TS-422/423/425-165-N002, Rev 00, shall remain unchanged.