



CLARIFICATIONS ON TECHNICAL SPECIFICATION FOR OXYGEN DOSING SYSTEM
1X800 MW COAL BASED NORTH CHENNAI TPP STAGE –III-BTG

SPECIFICATION NO.: PE-TS-423-154A-A002
 CLARIFICATION NO # 1
 REV. NO. 00 DATE: 24/03/2017
 Page 1 of 2

The following clarifications with respect to Technical Specification for oxygen dosing system (BHEL's Technical specification no. **PE-TS-423-154A-A002**) shall apply. Bidder's to comply the same.

CLARIFICATIONS ON TECHNICAL SPECIFICATION FOR OXYGEN DOSING SYSTEM:

Clarification asked by M/s Positive metering pumps (I) Pvt. Ltd. Unit-3 via email dated 20/03/2017 (Not in Pre-bid clarification format)

CLARIFICATION CLAUSES/PAGE NUMBERS AND FINAL RESOLUTION:

Sl.no.	SECTION	SUB-Section/ Description	Clause no	Page no	Existing clause/details	Bidder's clarification	BHEL reply
1.	I	I-A/SPECIFIC TECHNICAL REQUIRMENTS MECHANICAL / ANNEXURE-II/ SUB- VENDOR LIST	3,5,7	20 OF225	SUB- VENDOR LIST FOR OXYGEN DOISNG SYSTEM:	The Sub vendor list (Annexure-II) of Ball valve, Needle valve, PRCRV, PRV, Fittings Swage lock/Parker/Hamlet makes given, we have to add PANAM ENGINEERS in the sub vendor list. As this make is already approved with the NTPC-North karanpura, NTPC - Tanda thermal project. Please provide the PANAM engineers approval for this project. We will submit you the credentials ASAP.	Bidder to follow tender technical specification requirement. However, any additional sub-vendor shall be subject to bhel and customer approval during detailed engineering stage after award of oxygen dosing system.
					CHECK VALVE/BALL VALVE/	HAMLET-USA SWAGELOK-USA PARKER-USA	
					PRESSURE REDUCING VALVE	TESCOM-USA SWAGELOK-USA	
					NEEDLE VALVE & PRESSURE SAFETY VALVE	HAMLET-USA SWAGELOK-USA PARKER-USA	
2.	I	I-A/SPECIFIC TECHNICAL REQUIRMENTS MECHANICAL / ANNEXURE-II/ SUB- VENDOR LIST	12	21 OF225	SUB- VENDOR LIST FOR OXYGEN DOISNG SYSTEM:	The Sub vendor list (Annexure-II) of Mass flow controller (Emerson) Brooks single make provided we have to introduce	Bidder to follow tender technical specification requirement. However, any additional sub-vendor shall be subject to bhel and
					MASS FLOW CONTROLLER	BROOK'S (EMERSON)	



**CLARIFICATIONS ON TECHNICAL SPECIFICATION FOR OXYGEN DOSING
SYSTEM
1X800 MW COAL BASED NORTH CHENNAI TPP STAGE –III-BTG**

SPECIFICATION NO.: PE-TS-423-154A-A002

CLARIFICATION NO # 1

REV. NO. 00

DATE: 24/03/2017

Page 2 of 2

							the E&H make for the same. Please provide your confirmation accordingly we will provide you the credentials of the Mass flow controller.	customer approval during detailed engineering stage after award of oxygen dosing system.
--	--	--	--	--	--	--	---	--
