

Ref. No. : PE/PG/BIF/E-5832/2017/CORRIGENDA/02

Date : 14.02.2018

CORRIGENDA / ADDENDUM-02

SUBJECT: 2X660 MW BIFPCL MAITREE KHULNA STPP-BANGLADESH

OPEN TENDER ENQUIRY FOR PLATE HEAT EXCHANGERS (PHE)

Our Ref : ENQUIRY No : PE/PG/BIF/E-5832/2017, Dtd. 18.01.2018

DUE DATE
17-Feb-2018
BY 02:00 PM (IST)

Following pre-bid clarification is being issued for the subject tender enquiry:

<u>Clause No.</u>	<u>BHEL Specification</u>	<u>BHEL Clarification</u>
Tech specs , Datasheet – A , Point no. 2.5	No minimum heat transfer Area	Follow specification.
Tech specs , Datasheet – A , Point no. 6.9	Material Grade shall be SAE 1045	Equivalent or superior material may be accepted during detailed engineering, subject to proper justification and its acceptance by end customer. Follow specification.

Bidders are requested to submit their offer on or before this date & time.

Thanking You.

For & on Behalf of BHEL,

Ashish Kumar Gupta
14/02/18
Ashish Kumar Gupta
Dy. Manager/PG-I