



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT

PROJECT : 2X660 MW ENNORE SEZ STPP
PACKAGE : STEEL GATE/GLOBE/NR VALVES (WATER SYSTEM)

DATE: - 19.04.2017

Corrigenda/Addenda-1

Reference: i) Enquiry No. E-5571/2017 Dtd. 10.04.2017

Due Date : 05/05/2017 (02:00 PM)

Subject: Technical Clarification

This Corrigendum is being issued for technical clarifications as below: -

"All NRVs mentioned in enquiry Data Sheet-A are of swing check(SC) type.

Accordingly, NRVs at S. No. 9, 10 & 11 of Data Sheet-A shall be of Type-B of API-594".

All bidders to quote accordingly.

All other terms and conditions shall remain unchanged.

Regards

Anil Kumar Pal
19/4/17

Anil Kumar Pal

Sr. Manager

PG-II-2