



**BHARAT HEAVY ELECTRICALS LIMITED**  
**PROJECT ENGINEERING MANAGEMENT, NOIDA**

Date-5-May-26

**CORRIGENDUM- 02**

<b>PROJECT</b>	<b>:</b>	<b>FRAMEWORK AGREEMNT (RATE CONTRACT)</b>
<b>PACKAGE</b>	<b>:</b>	<b>CONTROL VALVES- OTHER THAN FDV</b>
<b>ENQUIRY NO</b>	<b>:</b>	<b>77/26/6016/SUM dated 22.05.2026</b>
<b>SUBJECT</b>	<b>:</b>	<b>Clarification on Technical Specification and Tender due date extension</b>

Type of Corrigendum			
Technical Corrigendum -	<input checked="" type="checkbox"/>	Commercial Corrigendum -	<input type="checkbox"/>

Bidders are requested to note:

1. Clarification on Technical Specification to the tender attached as per Annexure-1
2. Due date & time of bid submission has been extended up to 12.05.2025 @ 01.00 PM. Bid opening shall be done at 04:00 PM on the due date.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

**Kumar Suman Saurabh**  
**Manager/CMM**

## Annexure-I to Corrigenda-2

Please refer Technical Specification for the following tag no.:-

SL. NO.	Specification Ref.	Datasheet Ref./ Clause Ref.	As exists	Modified to
1	Technical specification PE-TS-20-145-H104-B	Clause no. XVIII- For tentatively 12 projects, all positioners shall be HART based. For the rest 9 projects, it will be a combination of HART as well as PROFIBUS based smart positioners. Bidder to quote for these smart positioners as per the SCHEDULE OF PRICES.	--	Clause no. XVIII- For tentatively 12 projects, all positioners shall be HART based. <b>Rest of the 9 projects shall comprise of total 15 units. The tentative quantity of control valves in each unit shall be 35 nos., out of which approximately 50% shall be considered as PROFIBUS based smart positioner.</b> Bidder to quote for these smart positioners as per the SCHEDULE OF PRICES.