



Ref. Enquiry No.: PW/PE/PG/TAN/E-5469/2016 Dt. 09.02.2017

DUE DATE
08.03.2017
BY 10:00 A.M.

CORRIGENDA-2

Date:-21.02.2017

PACKAGE: Fuel Oil Unloading & Storage system

PROJECT: 1 x 800 MW North Chennai Stage-III BTG

Enq. No.: PW/PE/PG/TAN/E-5469/2016 Dt. 09.02.2017

Sub: Corrigenda-2 for Enq. No. PW/PE/PG/TAN/E-5469/2016 Dt. 09.02.2017

Regarding above subject, please find enclosures as below.

1. Pre Bid Clarification Schedule (No. of pages-01)
2. Amendment On Technical Specification (No. of pages-01)

With Regards,
For & on behalf of BHEL

(Vinit Kumar Verma)
Sr Engineer/PG-II-1/ BHEL-PEM

Vinit Kumar Verma
Sr. ENGINEER/PG-II-1,
BHEL/PS-PEM
POWER PROJECT ENGINEERING INSTITUTE,
PLOT NO. 25, SECTOR - 16A, NOIDA (UP)
(OFF) 0120-4368837

Regd. Office:
BHEL House
Siri Fort
New Delhi-110049

PRE BID CLARIFICATION SCHEDULE				
Project:	1 x 800 MW North Chennai Stage-III BTG			
Package:	Fuel Oil Unloading and Storage System			
.				
Sr.No.	Section/Clause/ Page No.	Statement of the referred clause	Clarification required	BHEL Reply
1	Tech Spec, Sec IA, page no. 95 of 261	MANDATORY SPARE	Both referred clause calls for mandatory spares. Spares given in page 208 for C&I are not applicable. Hence we are considering spares given in page no. 95 of 261. Please confirm.	Bidder to consider the mandatory spares for erection hardware (S.No viii Page 210 of 261) as mentioned in C&I specification along with mandatory spares mentioned in Annexure-IV(Page 95 of 261)
	Tech Spec, page no. 208 of 261	ANNEXURE IV : MANDATORY SPARES		



**AMENDMENT ON TECHNICAL SPECIFICATION FOR
FUEL OIL UNLOADING AND STORAGE SYSTEM
1x800 MW TANGEDCO NORTH CHENNAI TPP**

SPECIFICATION NO.: PE-TS-423-166 –A101

AMENDMENT NO # 1

REV. NO. 00 DATE: 21/02/2017

Page 1 of 1

_AMENDMENT / ADDITION TO EXISTING CLAUSES OF FUEL OIL HANDLING SYSTEM TECHNICAL SPECIFICATION.

BIDDER TO NOTE THAT EXISTING DISCRIPTION AS APPEARING IN

THE SPECIFICATION STANDS DELETED / MODIFIED OR ADDED AND CLAUSES /
DETAILS AS MENTIONED IN “AMMENDMENT (TO BE READ AS)” COLUMN SHALL BE
APPLICABLE AND COMPLIED BY THE BIDDER.

S.no	CLAUSE	EXISTING DISCRIPTION	AMENDMENT (TO BE READ AS)
<u>1</u>	5.19 page 26 of 261	Bidder to provide minimum 24 nos., M33 anchor bolts for Condensate Storage Tank , irrespective of calculation for tank stability.	Bidder to provide minimum 24 nos., M33 anchor bolts for Condensate Storage Tank even if by calculation the number arrived is less than 24 .However if during calculation for tank stability if number of anchor bolt are more than 24 ,then actual number of anchor bolt to be provided.
2	3.1.0 , S.no 5) Page 16 of 261	For HSD day tank, minimum 4 nos. anchor bolts (M33 grade) to be considered irrespective of calculation.	For HSD day tank, minimum 4 nos. anchor bolts (M33 grade) to be considered even if by calculation the number arrived is less than 4 .However if during calculation for tank stability if number of anchor bolt are more than 4 ,then actual number of anchor bolt to be provided.