



**TENDER ENQUIRY FOR SCREENED CONTROL CABLE FOR 2X660MW
SURATGARH STPS , STAGE-V**

Date: 11.06.2014

CORRIGENDA-3

Tender Enquiry no.: PE/PG/SG5/E-4438/14 Dated 19.05.14

DUE DATE
16-JUNE-2014
10.00 AM

1) **CLAUSE REFERENCE OF TECHNICAL SPECIFICATION : DATASHEET-A, CLAUUE-10.0 (INDIVIDUALLY SCREENED)** – Following Sub-clause is added under Clause-10.0:


d) Min. thickness (Micron): 28 micron

2) **CLAUSE REFERENCE OF TECHNICAL SPECIFICATION : DATASHEET-A, CLAUUE-11.0 (OVERALL SCREENED)** – Following Sub-clause is added under Clause-11.0:

d) Min. thickness (Micron): 55 micron

This is for your information.

With Regards,
For & on behalf of BHEL


(Isha Rawat)
Sr.Engr/PG-II-1
BHEL-PEM

Please reply to:

Isha Rawat, Sr Engineer
PG-II-1

Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM,Noida-201301 (U.P.)

Tel No. 0120-4213577/4368774, Fax: 0120-4329106