



Ref No. : PE/PG/EN1/E-4881/2015

Date: 27.07.2015

CORRIGENDA / ADDENDA-3

Tender Enquiry no.: PE/PG/EN1/E-4881/2015

Date: 05.06.2015

DUE DATE
22-AUG-2015
02:00 PM

Subject: Due date extension for offer submission and Amendment in Technical Specification for "AIRCONDITIONING SYSTEM" of "2x660 MW ENNORE SEZ STPP".


Our Ref: i) Tender Enquiry no.: PE/PG/EN1/E-4881/2015 Date: 05.06.2015

ii) Corrigenda/Addenda-1 Dtd. 04.07.2015

iii) Corrigenda/Addenda-2 Dtd. 08.07.2015

1. Bid submission date against Tender Enquiry PE/PG/EN1/E-4881/2015 Dated 05.06.2015 is extended till **22.08.2015 (02.00 PM)**. The Techno-Commercial Bids shall be opened on **same day at 03.00 PM**.
2. There is Amendment in Technical Specification. Amendment details are enclosed herewith.

All other terms & conditions shall remain unchanged.

With Regards,
For & on behalf of BHEL

Akash Verma
Engineer/PG-II-2

Please reply to:

Akash Verma/ PG-II-2

Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM,Noida-201301 (U.P.)

Tel No. 0120-4368960



**AIR CONDITIONING SYSTEM
ENNORE TPS
(2X660 MW)**

SPECIFICATION NO. PE-TS-412-553-A001

ADDENDUM No. 4

DATE: 23.07.2015

SHEET 1 OF 2

ENNORE SEZ
(2x660 MW)

ADDENDUM No. 4

(TECH SPEC No. PE-TS-412-553-A001)

AIR CONDITIONING SYSTEM

बी एच ई एल 	AIR CONDITIONING SYSTEM ENNORE TPS (2X660 MW)	SPECIFICATION NO.PE-TS-412-553-A001
		ADDENDUM No. 4
		DATE: 23.07.2015
		SHEET 2 OF 2
ADDENDUM No. 4 TO THE TECHNICAL SPECIFICATION PE-TS-412-553-A001 AIR CONDITIONING SYSTEM OF ENNORE SEZ (2X660MW)		
1. AMENDMENT TO EXISTING CLAUSES OF THE TECHNICAL SPECIFICATION		
S.No	Clause	To Be Read As (Amendment)
1.	Volume IIB, section C2-C,PAINTING SPECIFICATIONS	Additional requirement: Final coat of paint on all the equipment's / item covered under the package shall be done at the time of handing Over of package.
2.	Volume IIB, section C1, SPECIFIC TECHNICAL REQUIREMENT.	All the instruments /equipment's/electrical items shall be provided & designed with maximum star rating as available in line with energy conservation policies notified by BEE, GOI at the time of supply