



Dt. 24/11/2021

Package : BUTTERFLY VALVES (STEAM SERVICES)

Project : 1x660 MW SAGARDIGHI EXTENSION PROJECT UNIT 5.

GeM Bid No. : GEM/2021/B/1618187 dated 23.10.2021

Corrigendum-4

Sub: Extension of due date for offer submission and change in Technical Parameters.

- A) Due date of offer submission for subject tender is extended till 01/12/2021 (04:00 PM). Techno-Commercial Bids shall be opened on same day at 04:30 PM.
- B) Painting requirement in Clause No: 12.0 of Specific technical requirements butterfly valves (Steam Service) - Specification No: PE-TS-445-100-M016 (Sheet 6 of 8) to be corrected as follows:
- a) Surface preparation shall be done by means of sand blasting, which shall conform to SSPC SP10/NACE 2/Sa2½ Standard.
 - b) Primer Coat shall consist of one coat (minimum DFT of 100 microns) of epoxy resin based zinc phosphate primer.
 - c) Intermediate Coat (or Under Coat) shall consist of one coat (minimum DFT of 100 microns) epoxy resin based paint pigmented with Titanium Dioxide.
 - d) Top Coat shall consist of one coat (minimum DFT of 75 microns) of epoxy paint of approved shade / aluminum color with glossy finish. Additional one coat (minimum DFT of 25 microns) of Finish Coat of polyurethane shall be provided.
 - e) Total DFT of paint system shall not be less than 300 microns.

**Ashutosh
Sharma**

Digitally signed by
Ashutosh Sharma
DN: cn=Ashutosh
Sharma, o, ou,
email=ashutosh.sharma
@bhel.in, c=US
Date: 2021.11.24
14:57:39 +05'30'

Ashutosh Sharma

Dy. Manager/PG-I

BHEL-PEM