

Ref. Enquiry No.: PW/PE/PG/TAN/E-5469/2016 Dt. 09.02.2017

DUE DATE
08.03.2017
BY 10:00 A.M.

CORRIGENDA-4

Date:-04.03.2017

PACKAGE: Fuel Oil Unloading & Storage system

PROJECT: 1 x 800 MW North Chennai Stage-III BTG

Enq. No.: PW/PE/PG/TAN/E-5469/2016 Dt. 09.02.2017

Sub: Corrigenda-4 for Enq. No. PW/PE/PG/TAN/E-5469/2016 dated 09.02.2017

Regarding above subject, please find below the pre-bid query received from the bidder along with BHEL reply and quote for subject tender accordingly: -

Query - Drwg. :Layout for day oil tank farm area , Drwg. No. PE-DG-423-166-A001 there are 2 separate pipe lines to plant drain and local sump pit whose locations are not shown in the plot plan Pg 38 of 261. Kindly mention the location. In addition we understand that for these 2 lines scope of both supply and erection is in our scope.

BHEL Reply:- Bidder to terminate approx. 10 meter from dyke area . Location shall be provided during detail engineering. These 2 lines scope of both supply and erection is in bidder scope.

With Regards,
For & on behalf of BHEL

(Rohit Juneja)
Sr Engineer/PG-II-1/ BHEL-PEM

#

ROHIT JUNEJA
Sr. ENGINEER/PG-II-1,
BHEL/PS-PEM
POWER PROJECT ENGINEERING INSTITUTE,
PLOT NO. 25, SECTOR - 16A, NOIDA (UP)
(OFF) 0120-4368848

##

Regd. Office:
BHEL House
Siri Fort
New Delhi-110049