



**OPEN TENDER ENQUIRY FOR DISTRIBUTION BORADS
FOR 1X 800 MW GSECL WANAKBORI STPP UNIT 8**

Ref No. : PE/PG/WAN/E-5351/2016

Date: 03.10.2016

CORRIGENDUM/ ADDENDUM-01

Tender Enquiry no.: PE/PG/WAN/E-5351/2016, Dated: 13.09.16

DUE DATE
04 OCT 2016
10.00 A.M

Replies to pre bid queries of bidders for "Distribution Board" tender are as below:-

S No.	Bidder's Query	BHEL PEM reply
1	For LDB TRF whether SFU shall be provided in primary side or both side primary & secondary. Kindly confirm.	Type of Incomer & outgoing for LDB already mentioned in technical specification. Bidder to follow specification.
2	In data sheet clause no.-3.11-j Transformer is tick with cast resin & non-encapsulated. As discussed with TRF manufacturer both are not possible for TRF. For same manufacturer suggested resin impregnated type TRF. Kindly confirm.	Bidder to note that the transformer shall be Cast resin type. Further, regarding Non-encapsulation, it is to be noted that this Transformer shall be housed in LDB. (Refer BOQ cum price schedule where it is clearly mentioned that the LDB shall be suitable for housing this Transformer). Also, refer clause no. 3.1.3 of section - II.
3	In data sheet clause no.-3.12-a DCLDB, Two incomer is tick. Assuming one incomer will be feeded from 220 V DC (DCDB) & another will be feeded form emergency supply 415VAC hence 415AC to 220VDC convertor will be required. Please confirm. Whether same is required or not.	DC lights will be ON all the time - normally from station A.C. Supply, but on its failure, from station D.C. supply through automatic switching. On failure of AC supply connected to the panel, under voltage relay shall drop out and shall switch ON the incomer DC contractor and thus the DC supply to lighting Circuit. Bidder to keep necessary provision as applicable.

All bidders are requested to visit the website www.bhel.com (Tender Notifications Section) or www.bhelpem.com. All future corrigenda/addenda, if any, for this tender shall be hosted on above websites.

Mazhar Wahab
03/10/16
MAZHAR WAHAB
Sr. Engineer/PG-11.

Please reply to:

Md. Mazhar Wahab/ Sr. Engr./Gaurav Jain, Mgr

PGI-I-BHEL-PEM,

Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
Noida-201301 (U.P.)

Tel No. 0120-4213606/ 4368835