

**OPEN TENDER ENQUIRY FOR DISTRIBUTION BORADS
FOR 1X 800 MW GSECL WANAKBORI STPP UNIT 8**

Ref No. : PE/PG/WAN/E-5351/2016

Date: 13.10.2016

CORRIGENDUM/ ADDENDUM-03

Tender Enquiry no.: PE/PG/WAN/E-5351/2016, Dated: 13.09.16

DUE DATE
15 OCT 2016
10.00 A.M

Replies to pre bid queries of bidders for "Distribution Board" tender are as below:-

S No.	Bidder's Query	BHEL PEM reply
1	Provide specifications for LP-E24.	Same shall as per AC normal Outdoor Type Lighting Panel. However these panels shall be fed from 3kVA Transformer & provide 24V power supply at outgoings used for 24 V maintenance Lighting. Transformer shall be housed inside panel itself and manufactured as per IS: 11171 (Refer clause no. 2.0 of Datasheet-A)
2	Provide rating of Incomer of LDB/WDB.	Bidders to follow the specification.

All bidders are requested to visit the website www.bhel.com (Tender Notifications Section) or www.bhelpem.com. All future corrigenda/addenda, if any, for this tender shall be hosted on above websites.

Mazhar
13/10/16
MAZHAR WAHAB
Sr. Engineer /PGT

Please reply to:
Md. Mazhar Wahab/ Sr. Engr./Gaurav Jain, Mgr
PGI-I-BHEL-PEM,
Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
Noida-201301 (U.P.)
Tel No. 0120-4213606/ 4368835