

Ref. No. PE/PG/TAN/E-5409/2016-02
Enquiry No.: PE/PG/TAN/E-5409/2016
Date: 27/12/2016

**1X800MW TANGEDCO NORTH CHENNAI STAGE-III BTG
DOUBLE GIRDER EOT CRANE ABOVE 50T TO 150T**

CORRIGENDA / ADDENDA-2

Dear Sirs,

Please find below pre-bid query along with BHEL's reply for your information:-

S. No.	Section/Clause /Page No.	Statement of the referred clause	Clarification Required	BHEL Reply
1.0	CCD / Wheel load diagram	Maximum LT wheel load given as 33T	Whereas from our calculation maximum LT wheel load (without impact) shall be 34.7T.	Bidder to note that 34.7T LT wheel load (without impact) is acceptable.

In Corrigenda/Addenda-1 (Ref No. PE/PG/TAN/E-5409/2016-01), project name may please be read as **"1X800MW TANGEDCO NORTH CHENNAI STAGE-III BTG"**.

All bidders are requested to quote accordingly.

With Regards,
For & on behalf of BHEL

Rohit Juneja
SR. ENGINEER/PG-II-1

ROHIT JUNEJA
SR. ENGINEER/PG-II-1,
BHEL/PS-PEM
POWER PROJECT ENGINEERING INSTITUTE,
PLOT NO. 25, SECTOR - 16A, NOIDA (UP)
(OFF) 0120-4368848.#

Regd. Office:
BHEL House
Siri Fort
New Delhi-110049