



Enquiry Ref. No.:- PE/PG/THD/E-6763/2021 dated 16.09.2021

Project : 2X660MW KHURJA SUPER THERMAL POWER PROJECT

Package: Lighting Fixtures, Lamps & Misc. items

DUE DATE
04.10.2021
BY 02:00 P.M.

Ref. :- PE/PG/THD/E-6763/2021/C1

Date 27.09.2021

CORRIGENDUM-1

Following points shall be part of NIT

1. In the BOQ, detailed description of item 7.01 to be read as "20 mm dia flexible electrogalvanised **TERNE** coated conduits, 1.6 mm thick".
2. Additional clarifications with respect to item no. 10, "Green Building Compliance" of BOQ :
 - (a) Area details for Green building shall be shared during detailed engineering stage.
 - (b) Type of Sensor, Dimmer & control systems : Bidder to read the entire specification clause by clause including section-I, section-II, Datasheet-A, Additional technical details, Quality plan, Annexure-2 etc. Bidder to specifically read the Annexure-2 of the specification "Criteria under GRIHA requirement".
3. Due date of the tender is extended to 2:00 P.M. of 04.10.2021, bid shall be opened on 04.10.2021 at 5:00 PM.

All other terms and conditions shall remain as per NIT and subsequent corrigendum, if any.

With Regards,

(Saumya Pandey)
Dy Manager/PG-I
BHEL-PEMSaumya Pandey
DY MANAGER/PG-I,
BHEL/PS-PEM
POWER PROJECT ENGINEERING INSTITUTE,
PLOT NO. 25, SECTOR - 16A, NOIDA (UP)
(OFF) 0120-4213543Regd. Office:
BHEL House
Siri Fort
New Delhi-110049