

<b>Project</b>	<b>2x800 MW NTPC Singrauli TPP Stage-III project</b>
<b>Package</b>	<b>Oil Filled Service Transformer</b>
<b>Enquiry No. &amp; Date</b>	<b>77/25/6132/AJA Dt. 17.09.2025</b>
<b>Date</b>	<b>18.11.2025</b>
<b>Subject</b>	<b>Corrigendum-6: Technical corrigenda and due date extension upto 25.11.2025</b>

**Please note the following:**

1. Attached technical corrigenda is issued for above mentioned tender enquiry (refer attached Annexure-A).
2. The due date for offer submission is extended up to 25.11.2025; 02:00 PM and Part-1 bid opening time to 25.11.2025; 04:00 PM. Please ensure submission of bids on or before due date.

All other terms and conditions are unchanged.

Thanking You.

Yours Sincerely,

Ajay Kumar  
(Sr. Engineer / PG-I/ BHEL-PEM)

Ajay Kumar  
Sr. Engineer / PG-I, BHEL PS-PEM,  
3<sup>rd</sup> Floor, BHEL Sadan Building,  
Plot No. 25, Sector – 16A, Noida (UP) 201301, INDIA  
Tel: 0120 2218550

Regd. Office  
BHEL House Siri Fort  
New Delhi-110049

**Oil Filled Transformer for 2 X 800 MW NTPC SINGRAULI STPP STAGE-III**

**Annexure-A to Corrigendum**

S.No.	Specification Reference				Existing Provision				Modified Clause					
	Section/Part	Sub-Section	Clause No.	Page No.										
1	Technical Specification	TECHNICAL DATA PART A	3.16.3 & 3.16.4	11 of 70	3.16.3	Pressure Relief Device	To be provided for transformer $\geq$ 2MVA		3.16.3	Pressure Relief Device	To be provided for all rating transformer			
					3.16.4	Diaphragm type explosion vent	To be provided for transformer $<$ 2MVA		3.16.4	Diaphragm type explosion vent	NA			
2	Technical Specification	TECHNICAL DATA PART A	4.0	12 of 70	4.0	<b>PERFORMANCE PARAMETERS</b>				4.0	<b>PERFORMANCE PARAMETERS</b>			
					4.1	Maximum guaranteed Losses at 75°C				4.1	Maximum guaranteed Losses at 75°C (for 2500, 2000, 1600, 630 KVA, 11/0.433kV transformers)			
					4.1.1	Maximum 50% Load losses at rated frequency and 100%voltage	kW	2.8	Losses as per Energy Efficiency Level-2 of IS-1180 (applicable starting from April 2022)/ STAR-2 rating or better as per BEE guideline	4.1.1	Maximum 50% Load losses at rated frequency and 100%voltage	kW	Losses as per Energy Efficiency Level-2 of IS-1180 (applicable starting from April 2022)/ STAR-2 rating or better as per BEE guideline	
					4.1.2	Maximum 100% Load losses at normal ratio, rated current and 75 deg. C	kW	30		4.1.2	Maximum 100% Load losses at normal ratio, rated current and 75 deg. C	kW		
									4.2	Maximum guaranteed Losses at 75°C (for 2500 KVA, 11/3.45kV transformers)				
									4.2.1	Maximum NO Load losses at rated frequency and 100%voltage	kW	2.8		
									4.2.2	Maximum Load losses at normal ratio, rated current and 75 deg. C	kW	30		

*(Svny)*  
(Svnya Dev)  
(17/11/25)

*Sour*  
*N*  
*(17/11/25)*  
(SOURABH TIWARI)

*P. Datta*  
(P. Datta)  
(17/11/25)