

Ref. Enquiry No.: PE/PG/MEI/E-5439/2016 Dated: 12.01.2017

DUE DATE
04.02.2017
BY 02:00 P.M.

CORRIGENDA-1

With reference to Section-1, Sizing Data Sheet-A-2, notes -2, page 11 of 63 of Technical Specification, please consider the Specification (No. PE-TS-422-142-N101) amended as below:

Clause as mentioned in Technical Specification	Amended Clause
Low capacity steam pressure reducing valve min. flow at 10% valve lift shall correspond to the passing capability of low capacity steam pressure reducing valve at 95% valve lift.	High capacity steam pressure reducing valve (ASV-22) min. flow at 10% valve lift shall correspond to the passing capability of low capacity steam pressure reducing valve (ASV-65) at 95% valve lift.

With Regards,
For & on behalf of BHEL

(Vinit Kumar Verma)
Sr Engineer/PG-II-1/ BHEL-PEM

Vinit Kumar Verma
Sr. ENGINEER/PG-II-1,
BHEL/PS-PEM
POWER PROJECT ENGINEERING INSTITUTE,
PLOT NO. 25, SECTOR - 16A, NOIDA (UP)
(OFF) 0120-4368837

Regd. Office:
BHEL House
Siri Fort
New Delhi-110049