

## CORRIGENDUM

SI. No.	Existing Clause	New Clause
Section-1 Clause-1.3.1 Specific technical requirement	-	h. There is requirement of PMU with associated hardwares viz. GPS, L3 Lan Switch, LIU for line bays. The same shall be procured through separate package and to be mounted in Line relay panel. Necessary space shall be considered on the panel. Cut out details shall be shared during detailed engineering.

*Rajat*  
30/01/2023

*Sanjiv*  
30/01/2023