



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-23-Jul-19

CORRIGENDUM- 01

PROJECT	:	1X660MW UPRVUNL PANKI EXTN
PACKAGE	:	VENTILATION SYSTEM
ENQUIRY NO	:	E-6254/2019 Dated. 05.07.2019
SUBJECT	:	PRE- BID CLARIFICATION + % OF MINIMUM LOCAL CONTENT

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☒

Please note the following:

- 1. Reply to Pre Bid Query (of 01 Page) attached with this corrigendum shall be treated as part of NIT.**
- 2. % of Minimum Local Content in line with Make In India notification for Ventilation System Package shall be 100%.**

All the other terms and conditions of the tender enquiry shall remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Sharad Chandra
Dy. Manager



**1 x 660 MW UPRVUNL PANKI
EXTN. VENTILATION SYSTEM
PRE-BID CLARIFICATION
SCHEDULE.**

**SPECIFICATION No : PE-TS-426-
554-A001 (REV - 0).**

SECTION :

SUB-SECTION :

REV.NO. 00

DATE:30.03.2019

SHEET : 1 OF 1

PRE – BID CLARIFICATION SCHEDULE

SL.NO.	SECTION / CLAUSE / PAGE NO.	STATEMENT OF THE REFERRED CLAUSE	CLARIFICATION REQUIRED
1.	Sl.No. 7, Page 27 of 604, Sub Section – C1 of Section -1.	Specific requirement	Mentioned Efficiency of the UAF as 70%. Where as in Cl.No. 25.6.2.3, Page No. 49 of 604 saturation efficiency mentioned 60%. Kindly confirm which is correct.
2.	Price Schedule, Sl.No. (1) & (2) , Suction & Discharge Plenum.	Customer Specification / MOC.	Kindly clarify the Suction and Discharge Plenum. In the Specification Under Clause No. Casing and Tank shall be Epoxy Paint
3.	Clause No. 4 of Section – 1, Sub-section : C1 Pg 23 of 604.	2 Nos. UAF...	Capacity of Pump indicated 90 CMH at 25 mm Head, is it OK. whereas efficiency of the UAF as indicated around 70%.
4.	SL .No. 17 of Price Break-up under Annexure-I	Local Control Panel.	Is it in Vendors Scope of Supply. Please Confirm. since there is no mention of the same item in the Electrical Scope Matrix.

**BHEL
Reply**

**70 % efficiency
shall be
considered.**

**Spec
requirement is
clear .Kindly
comply with
spec**

**Vendor to
follow spec
requirements**

**Local control panel shall
be provided by vendor.
However , push button
station for emergency
operation shall be
provided by BHEL as per
scope matrix at page 325
of 604.**

The bidder hereby clarifies that above mentioned are the only clarifications required on the technical specification for the subject package.