

Ref: BHE/PW/PUR/UKH-GEN/1193/Corrigendum 01

Date 26/11/2013

-----Page 1 of 1-----

To

ALL BIDDERS

Sub: Corrigendum -01 issue of Clarification & Amendment.

JOB: Dismantling of existing Generator stator assembly, erection, magnetic centre correction of rotor w.r.t stator , Commissioning and testing of new wound stator of Ukai Hydro Unit No.4.

Tender Specification Number: BHE/PW/PUR/UKH-GEN/1193

Bidders to kindly take note of the following:

=====

AA) Correction - Typographical error

The typographical error noticed in NIT of Vol I A has been corrected as given below;

<u>Sl No.</u>	<u>Broad Scope of Work as per page no.5 of NIT</u>	<u>Amended as</u>
<u>1</u>	CHEMICAL CLEANING OF BOILER UNIT #4 500 MW MSPGCL BHUSAWAL TPS	Dismantling of existing Generator stator assembly, erection, magnetic centre correction of rotor w.r.t stator , Commissioning and testing of new wound stator of Ukai Hydro Unit No.4

BB) Issue of Clarification.

Query 1: The contract duration as per tender document is 180 days. However the requirement of Engineer for mechanical dismantling and assembly is given as 210 days. Kindly Clarify

Clarification 1: Being R & M job and considering the defect liability period man days mentioned for mechanical dismantling and assembly is justified.

Query 2: Refer Chapter II of Vol I A, Sl No.C Winding of Stator: Kindly confirm the type of HV test to be carried out?

Clarification 2: HV tests to be carried out are AC RMS Voltage 50Hz and 60 Second duration.

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-01" against NIT-15577 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,
Yours faithfully,

AGM (Purchase)