



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-24-Jul-19

CORRIGENDUM- 02

PROJECT	:	1X660MW UPRVUNL PANKI EXTN
PACKAGE	:	VENTILATION SYSTEM
ENQUIRY NO	:	E-6254/2019 Dated. 05.07.2019
SUBJECT	:	PRE- BID CLARIFICATION

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☐

Please note the following:

- 1. Reply to Pre Bid Query (of 01 Page) attached with this corrigendum shall be treated as part of NIT.**

All the other terms and conditions of the tender enquiry shall remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Sharad Chandra
Dy. Manager



**1 x 660 MW UPRVUNL PANKI
EXTN. VENTILATION SYSTEM
PRE-BID CLARIFICATION
SCHEDULE.**

**SPECIFICATION No : PE-TS-426-
554-A001 (REV - 0).**

SECTION :

SUB-SECTION :

REV.NO. 00 DATE:

SHEET : 1 OF 1

PRE – BID CLARIFICATION SCHEDULE

SL.NO.	SECTION / CLAUSE / PAGE NO.	STATEMENT OF THE REFERRED CLAUSE	CLARIFICATION REQUIRED
1.	Section – 1, Sub Section – C1 Page 26 of 604,	Supply Air, Exhaust Air Fan.....	Who will supply Local Starter Panels for referred Fan. Please clarify.

BHEL REPLY:
Supply air fans,
exhaust fans and
ventilation fans
are provided with
local starters.

The bidder hereby clarifies that above mentioned are the only clarifications required on the technical specification for the subject package.