



## BHARAT HEAVY ELECTRICALS LIMITED/PEM-NOIDA

PROJECT: 4x270 MW BHADRADRI TPS

Date: 28.12.2017

PACKAGE: PA SYSTEM

ENQUIRY NO: E-5790/2017 Dtd. 29.11.2017

Ref:

1. ENQUIRY NO: E-5790/2017 Dtd. 29.11.2017


2. CORRIGENDA NO. 01 dated 19.12.2017

### CORRIGENDA 02

Following are certain BHEL Clarifications on subject tender:

| <u>Sl. No.</u> | <u>Tender Reference</u>                                                                                                          | <u>Query</u>                                                                                                                                                                                                                                                           | <u>BHEL Clarification for consideration by all bidders</u>                                                                                                                  |
|----------------|----------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <u>1</u>       | <b>Clause: 8.01.11,</b><br>Calls will be carried out through loudspeakers installed in the various locations across the Project. | Calls will be carried out through FCS & MCS, Loudspeakers will only make announcements.                                                                                                                                                                                | Noted                                                                                                                                                                       |
| <u>2</u>       | <b>GCC Rev. 06 (ITB) Clause 1,</b><br>Two signed and stamped copies of documents are required.                                   | Being an e-tender bid submission, no hard copies are required to be submitted.                                                                                                                                                                                         | Noted. Bidder to upload signed & stamped copies as a per e-tender requirements.                                                                                             |
| <u>3</u>       | BOQ CUM PRICE SCHEDULE<br>FORMAT                                                                                                 | Different Annexures attached with main price schedule are not matching.<br>For example, erection hardware is mentioned as per Annexure-D in main price schedule, however Annexure- 3D is for O&M Spare. Similarly Annexure- 3C for Erection Hardware is given 2 times. | Refer annexure as per description mentioned in the main un-priced schedule as well as in different annexures. The typo error in annexure name like A,B etc. can be ignored. |
| <u>4</u>       | Type-B Stations                                                                                                                  | Type B stations are mentioned outdoor in Specification VOLUME-II, SECTION-I (Under section 8.17) and Indoor in VOLUME-II-B, SECTION-D (Under section 6.3.2).                                                                                                           | Details mentioned in Section-I shall prevail over general description of Section-II-B, Section-D.                                                                           |
| <u>5</u>       | Type-B Stations                                                                                                                  | Type B stations are mentioned outdoor flame proof in Specification VOLUME-II, SECTION-I and only weather proof mentioned in VOLUME-II-B, SECTION-D.                                                                                                                    | Details mentioned in Section-I shall prevail over general description of Section-II-B, Section-D.                                                                           |

Bidders have to consider the above clarifications & bid accordingly.

  
28.12.17  
DHREER SINGH  
SR. ENGINEER/PG-IV