

BHARAT HEAVY ELECTRICAL LIMITED
PROJECT ENGINEERING MANAGEMENT

Ref Enquiry: PE/PG/KG1/E-4836/2015 (DT. 13.05.2015)

AMENDMENT - 1

PROJECT: 1 X 800 MW KOTHAGUDEM TPS

PACKAGE: **GENERATOR CIRCUIT BREAKER (GCB)**

SUBJECT: Clarification related to technical specification, PE-TS-410-510-E001 R0.

Following is brought to the attention of bidders in respect of specification requirements of Generator Circuit Breakers (GCB) for the 1 X 800 MW KOTHAGUDEM TPS project:

i) Section-C, Annexure-A VOLTAGE TRANSFORMER

Clause no	Change Description	Earlier Description	Revised Description
7.0	Change in "Rated VA" of VOLTAGE TRANSFORMER (VT)	a. 60VA b. 60VA c. 60VA	a. 75VA b. 75VA c. 75VA

ii) Section-C, BOQ-CUM-PRICE SCHEDULE OF GENERATOR CIRCUIT BREAKER.

SL.NO.	Change Description	Earlier Description	Revised Description
1.0(a)	"Main Item Description" at serial no. 1.0(a) changed.	COMPLETE INTERRUPTING CHAMBER WITH SURGE CAPACITOR, DISCONNECTOR SWITCH AND EARTH SWITCH OF ONE POLE.	ONE SPARE POLE ASSEMBLY COMPLETELY IDENTICAL TO MAIN POLE ASSEMBLY ALONG WITH ENCLOSURE SUITABLE FOR COMPLETE REPLACEMENT OF ANY OF THE MAIN POLES.