



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-27-Sep-19

CORRIGENDUM- 04

PROJECT	:	1X660 MW BHUSAWAL TPS UNIT-6
PACKAGE	:	D.M. PLANT
ENQUIRY NO	:	E-6298/2019 Dated. 02.09.2019
SUBJECT	:	TECHNICAL AMENDMENT

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☐

Please note the following:

- 1. Amendment-2 (of 1 Page) to TECHNICAL SPECIFICATION FOR D.M. Plant FOR 1X660 MW BHUSAWAL TPS UNIT-6 attached with this corrigendum shall be treated as part of NIT.**

All the other terms and conditions of the tender enquiry shall remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Sharad Chandra
Dy. Manager



**AMENDMENT TO TECHNICAL SPECIFICATION FOR DM
PLANT FOR 1X660 MW BHUSHAWAL TPS UNIT 6.**

SPECIFICATION NO.: PE-TS-415-163-A001

AMENDMENT NO # 2

REV. NO. 00

DATE: 27/09/2019

Page 1 of 1

The following modifications with respect to **TECHNICAL SPECIFICATION FOR DM PLANT** BHEL's Technical specification no **PE-TS-415-163-A001** shall apply. Bidder to note that existing clauses/details as appearing in the specification stands deleted / replaced and clauses/details as mentioned in "Modified to or Read as" column shall be applicable and complied by the bidder as listed below in **SCHEDULE A**.

MODIFIED CLAUSES/PAGE NUMBERS:

SCHEDULE- A

SI no.	Section	Sub-Section/ Description	Clause no	Page no	Existing clause/details	Modified to or Read as
1.	C	Clarified Water Analysis	-----.	134, 135, 136 of 485.	Clarified water analysis	Filtered water analysis.
2.	C	Piping	SI no 87-3.	15 of 485.	600 meter DM plant feed piping from Clarified water pump house where (DM Feed pumps are located) to DM plant. For details, please refer plot plan.	600 meter DM plant feed piping from Filtered water pump house where (DM Feed pumps are located) to DM plant. For details, please refer plot plan.
3.	C	Activated Carbon Filter	SI no 2.2.9.	146 of 485.	As per the Design Clarified Water Analysis	As per the Design Filtered Water Analysis
4.	C	Mandatory spares	5.5	113 of 485	Media for dual media pressure filters	SI no 5.5 shall be considered as deleted as the same scope is covered in 5.1, page number 113 of 485 of tender Technical Specification.
