



Bharat Heavy Electricals Limited

(A Govt. of India Undertaking)

पारेषण व्यापार समूह, नोएडा, ऊ.प्र. / TBG, Noida, U.P.

सामग्री प्रबंधन / Material Management

Tower-A, 5th Floor, Advant Navis IT Business Park, Plot-7,
Sector-142, Expressway Noida, Noida-201305

Phone: 0120-6748484, Fax: 0120-6748550, Email: rajeevroy@bhel.in

Subject: Corrigendum - 05 for extension of due date for submission of bids & technical clarification for supply of 400kV GIS-POWERGRID SS19 ITARSI PROJECT against BHEL NIT No: 48288.

Project : POWERGRID SS19 ITARSI PROJECT.

Equipment / Item : SUPPLY & SUPERVISISON OF 400KV GIS.

Enquiry No. / Date : 61Q2000107, DATED 20-08-2019, **CURRENT DUE ON: 11-10-2019**

TENDER SUBMISSION

The corrigendum - 05 has been uploaded in BHEL/CP Portal incorporating technical clarification & extension of due date for submission of offer against the above tender enquiry.

The due date for submission of offers has been extended up to **17-10-2019 at 14.00 Hrs** & bidder to ensure for submission of their offer on or before extended due date.

Thanking you

Enclosed:

- Annexure-A of corrigendum-05.

21-10-19
Rajeev Kr. Roy/MANAGER, TBM
राजीव कुमार रॉय / Rajeev Kumar Roy
प्रबंधक (टी.बी.एम.ग्रुप) / Manager (T.B.M.M.)
पारेषण व्यापार समूह / Transmission Business Group
भारत हेवी इलेक्ट्रिकल्स लिमिटेड
Bharat Heavy Electricals Limited
5th Floor, Tower-A, Advant Navis IT Business Park,
Plot No.-7, Sector-142, Expressway Noida-201305 (U.P.)

BOQ Item No	Existing Clause (as per Section-1 Rev.1)	CORRIGENDUM
1	3.1.8 Gas insulated Surge Arrestor (1.) Outdoor Surge Arrestor is being provided by BHEL as per tender SLD. Bidder shall conduct Insulation Coordination Study for establishing Surge Arrestor's rating and any other requirement for successful operation of GIS and cost of same shall be deemed included in scope of supply. Any additional item/ Surge arrester if required as per result of insulation coordination study within GIS shall be in GIS supplier scope. The study report shall be submitted for Approval. Please refer clause 11.2. of Section-2 of technical specification for scope involved for Insulation co-ordination details.	3.1.8 Gas insulated Surge Arrestor (1.) Outdoor Surge Arrestor is being provided by BHEL as per tender SLD. Bidder shall conduct Insulation Coordination Study for establishing Surge Arrestor's rating and any other requirement for successful operation of GIS and cost of same shall be deemed included in scope of supply. Any additional item / Surge-arrester if required as per result of insulation-coordination study within GIS shall be in GIS-supplier-scope. The study report shall be submitted for Approval. Please refer clause 11.2. of Section-2 of technical specification for scope involved for Insulation co-ordination details. (2.) Inline with the approved insulation cordination study, if additional LA is required, shall be outdoor type and vendor shall provide all the inputs i.e. technical parameters / details of LA. Outdoor LA is not in bidder's scope of supply.

10
10/10-2019
JAK

Sanjay
10/10/19.

Annexure - A