

Ref: PE/PG/MG1/E-6491/2020/Corrigendum 05

Date: 18/09/2020

Project: 4X270MW BHADRADRI TPS

Package: FIRE SEALING SYSTEM

Enquiry. No.: PE/PG/MG1/E-6491/2020 dated 17.08.2020

Subject: Corrigendum due to Technical clarification

With reference to the above Tender Enquiry, bidders to note the following:

S. No	As per Price Bid Format	Bidders' query	BHEL Clarification
1	PIPE SLEEVES - 200 NB , 2 HR RATING	Solution varies with Dia of pipe and material of pipe (PVC/MS) So kindly confirm the type of penetrations	Pipe diameter is already mentioned i.e. 200mm, material shall be PVC.

Thanking You

With regards

For & on behalf of BHEL

Karuna Kaushik

Engineer | PG II, BHEL PEM | Noida