



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-23-Jul-19

CORRIGENDUM- 06

PROJECT	:	1X660 MW BHUSAWAL TPS UNIT-6
PACKAGE	:	CONDENSATE POLISHING UNIT
ENQUIRY NO	:	E-6232/2019 Dated. 14.06.2019
SUBJECT	:	PRE- BID CLARIFICATION + % OF MINIMUM LOCAL CONTENT

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☒

Please note the following:

- 1. Reply to Pre Bid Query (of 01 Page) attached with this corrigendum shall be treated as part of NIT.**
- 2. % of Minimum Local Content in line with Make In India notification for Condensate Polishing Unit Package shall be 82%.**

All the other terms and conditions of the tender enquiry shall remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Sharad Chandra
Dy. Manager

PROJECT: 1X660 MW BHUSAWAL TPS UNIT-6
PACKAGE: CONDENSATE POLISHING UNIT
ENQUIRY NO: E-6232/2019 Dated. 14.06.2019

Sl No.	Bidder's Query	BHEL Reply Dtd. 23.07.2019
1.	Resin for CPU Plant for BHEL has UC of 1.7 in earlier projects. There are number of references for CPU plant which are running successfully with UC of 1.7 instead of 1.1. Recent tenders of BHEL are having UC of 1.7. Request you to accept the UC of 1.7 for Resin.	Bidder to note that resin specification requirement is clear in tender specification, In view of this bidder to follow the same.