



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date: 02 Nov 2020

CORRIGENDUM- 06

PROJECT	:	2 X 660 MW THDC KHURJA-TG
PACKAGE	:	CONDENSATE POLISHING UNIT
ENQUIRY NO	:	E-6521/2020 Dtd. 02.09.2020
SUBJECT	:	PRE- BID CLARIFICATION

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☐

Please note the following:

- 1. Reply to Pre-Bid Clarification attached with this corrigendum shall be treated as part of NIT.**

All the other terms and conditions of the tender enquiry shall remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Sharad Chandra
Manager/BOP

Sr. No.	Volume	Section	Clause No.	Page No.	Specification Requirement	Clarification	Reason for Clarification / Bidder's Assumption	BHEL Reply
1.	Technical Specification – VI, Part-A	VI Sub Section -IIC	18.01.02	695	The AMC shall cover total maintenance of all Analysers, Sample Handling System, Transmitters etc. coming under the scope of each system and shall include free repair / replacement of each items, replenishment of consumables, correction of problems (if any) and supply of expendable items.	Is it applicable for transmitter also as per clause requirement? Please clarify?	M/s BHEL is requested to clarify.	The clause is applicable for Transmitters of analysers.
2.	VOLUME IIB	SECTION - IA		308	Bidder to note that the spares and consumables (except regeneration chemicals i.e. HCL & NaOH) required for maintenance of the equipment during this O&M period shall be in bidder's scope of supply.	As per this clause, spare to be considered for all equipment during this O & M. Is it applicable for all Instruments also? Please clarify.	M/s BHEL is requested to clarify.	Technical specification is clear in this respect. As stated in technical specification all Instruments shall also be applicable.