



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-2-Jul-18

CORRIGENDUM- 06

PROJECT	:	2X800MW TANGEDCO UPPUR BTG
PACKAGE	:	VENTILATION SYSTEM
ENQUIRY NO	:	PE/PG/UPP/E-5919/2018 Dt. 20.04.2018

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☒

In reference to the above mentioned tender enquiry for **VENTILATION SYSTEM** package

Please note the following.

1. Due date has extended from **2-Jul-18** to **9-Jul-18** till **02:00 PM**. Bid opening shall be done at **03:00 PM** on the due date.
2. Reply of pre-bid query.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Vinit Kumar Verma
Dy. Manager



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Sl. No	Bidder's Query	BHEL reply
1.	Normally we take length of air washer 625 or 800 mm length of inlet and out air chamber and length of air washing chamber as 2000 mm. but the specification no where length of inlet and outlet air chamber has been indicated so you are requested to please confirm what should be the length of inlet & outlet air chamber as well as length of air washing chamber.	Sizing of Air washer shall be finalized during detailed engineering stage after award of the contract .
2.	What should be distance between the two header.	Sizing of Air washer shall be finalized during detailed engineering stage after award of the contract.
3.	As per your specification fine has to come in between pre filter and air washer so how gap you require in between air washer to fine filter and fine filter to pre filter do you need inspection hole / man hole for cleaning of fine filter. since as per the specification fine filter has to come in between air washer and pre filter there has to be man hole / inspection door in between but nothing is mentioned the specification about this.	inspection windows shall be provided for cleaning the filters as per cl 3.10 viii of specification section C1 and as shown in P&IDs.
4.	In specification you have given schematic drawing of air washer / UAF without pre filter and fine filter so can we get the schematic drawing of air washing / UAF along with pre filter and fine filter	air washer shall be provided with pre and fine filters as specified in the specification. P&IDs for air washer and UAF shall be submitted by vendor during detailed engineering stage for BHEL/Customer approval indicating all items required as per specification. 2x100% circulation centrifugal pumps are to be provided for UAFs as shown in P&ID attached with specification.