

Ref: PE/PG/MG1/E-6491/2020/Corrigendum 07

Date: 28/09/2020

Project: 4X270MW BHADRADRI TPS

Package: FIRE SEALING SYSTEM

Enquiry. No.: PE/PG/MG1/E-6491/2020 dated 17.08.2020

Subject: Corrigendum due to Amendment to Technical Specification

With reference to the above Tender Enquiry, bidders to note that Amendment to Technical Specification shall be applicable as per attached Annexure-III to Corrigendum 07.

All other terms & conditions of the tender shall remain unchanged.

Thanking You

With regards

For & on behalf of BHEL

Karuna Kaushik

Engineer | PG II, BHEL PEM | Noida



**AMENDMENT TO TECHNICAL SPECIFICATION FOR FIRE SEALING SYSTEM
FOR 4X270 MW BHADRADRI TPS**

SPECIFICATION NO.: PE-TS-411-507-E016

AMENDMENT NO # 1

REV. NO. 00 DATE: 23/09/2020

Page 1 of 1

MODIFIED CLAUSES AS BELOW.

Sr. No.	Vol. No.	Section/ Description	Clause no	Page no	Existing clause/details	Modified Clause
1		Technical Specification – Section I	1.1	1 of 2	This enquiry covers the Design, manufacturing, inspection & testing at manufacturer's works, proper packing, delivery to site, handling and erection & commissioning of Panel based Fire Sealing and fire coating System for cable openings through walls, floors & below panels, pipe sleeves and fire protection coating on installed cables conforming to this specification.	This enquiry covers the Design, manufacturing, inspection & testing at manufacturer's works, proper packing, delivery to site, handling and erection & commissioning of Panel or Powder/Mortar based Fire Sealing and fire coating System for cable openings through walls, floors & below panels, pipe sleeves and fire protection coating on installed cables conforming to this specification.
2		Technical Specification – Datasheet B	3.1	1 of 2	1) Fire stop system [Panel based]	1) Fire stop system [Panel or Powder/Mortar based]
3		Technical Specification – Section II	2.2.1	1 of 11	Panel based sealing system (Comprising encasing panels, cavity fill material & sealant).	Panel or Powder/Mortar based sealing system (Comprising encasing panels, cavity fill material & sealant).
4		BOQ CUM Unpriced Price Schedule	Sr. No. 1(4) & 2(4)		PIPE SLEEVES-200NB, 2 HOUR RATING	PIPE SLEEVES FOR 200NB PVC PIPE, 2 HOUR RATING