



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date: 16 Nov 2020

CORRIGENDUM- 08

PROJECT	:	2 X 660 MW THDC KHURJA-TG
PACKAGE	:	CONDENSATE POLISHING UNIT
ENQUIRY NO	:	E-6521/2020 Dtd. 02.09.2020
SUBJECT	:	PRE- BID CLARIFICATION

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☐

Please note the following:

- 1. Reply to Pre-Bid Clarification attached with this corrigendum shall be treated as part of NIT.**

All the other terms and conditions of the tender enquiry shall remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Sharad Chandra
Manager/BOP

Sr. No.	Volume	Section	Clause No.	Page No.	Specification Requirement	Clarification	Reason for Clarification / Bidder's Assumption	BHEL Reply
1.	Technical Specification Volume-IIB	IA	1.0	308	The bidder scope also covers the Operation and Maintenance (O&M) services for Preventive and Breakdown maintenance from the date of successful commissioning till handing over. The date of start of O&M services shall be communicated to successful bidder by BHEL site personnel.	As per our understating Operation and Maintenance (O&M) services shall starts immediately after commissioning of the Plant.	Commencement of Operation and Maintenance (O&M) services is required to estimate the spare requirement during Operation and Maintenance (O&M) period. M/s BHEL to clarify.	Bidder to refer the technical specification, as stated O&M services for preventive and breakdown maintenance shall starts from the date of successful commissioning till handing over. Total duration of the Operation and Maintenance services has been envisaged for twelve (12) months for complete Condensate Polishing Unit identified in price format/specification. Bidder to follow the same.