



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-18-Apr-19

CORRIGENDUM- 01

PROJECT	:	1X660MW UPRVUNL PANKI EXTN
PACKAGE	:	VENTILATION SYSTEM
ENQUIRY NO	:	E-6160/2018 Dated. 30.03.2019
SUBJECT	:	PRE- BID CLARIFICATION

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☐

In reference to the above mentioned tender enquiry for **VENTILATION SYSTEM** package

Please note the following:

- 1. Reply to Pre Bid Query (of 1 Page) attached with this corrigendum shall be treated as part of NIT.**

All the other terms and conditions of the tender enquiry shall remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Sharad Chandra
Dy. Manager



**1x 660 MW UPRVUNL
PANKI EXTN.
VENTILATION
SYSTEM PRE-BID
CLARIFICATION
SCHEDULE**

SPECIFICATION No : PE-TS-426-554-A001 (REV-0)

SECTION :

SUB-SECTION :

REV.NO. 00

DATE:17.04.19

SHEET : 1 OF 1

PRE – BID CLARIFICATION SCHEDULE

SL.NO.	SECTION / CLAUSE / PAGE NO.	STATEMENT OF THE REFERRED CLAUSE	CLARIFICATION REQUIRED	BHEL REPLY
1.	Sl.No. 2 Page-19 of 553, Sub Section – C1 of Section – 1.	Single Bank UAF.....	Mentioned Efficiency of the UAF as 70%. Where as in Cl. No. 25.6.2.3, Pg. No. 49 of 553 saturation efficiency mentioned 60%. Kindly confirm which is correct.	UAF efficiency of 70% to be considered.
2.	Clause No. 25.7.13.3, Page No. 66/553.	Customer Specification / MOC...	The Customer Specification / MOC of the diffuser grill shall be extruded as where in your Price Schedule Sl.No.3.3 & 3.4 indicated MS Grills - kindly confirm.	Extruded Aluminum Grills of minimum 2mm thk with powder coating are also acceptable. Necessary Amendment regarding the same shall be issued.