

**Work: Handling of materials at BHEL/Client's stores/storage yard, transportation to site of Erection, Erection, Testing & Assistance for commissioning and Trial Operation, including supply and application of Final Painting, of Boiler and its Auxiliaries, Air Pre-heaters, Ducts and Dampers, Boiler Integral Piping, Fans, Bowl Mills, Rotating Equipment, etc. of 1x525 MW set at Tuticorin TPS Stage IV, Megha Engineering & Infrastructures Limited (MEIL), Tuticorin, Tamil Nadu**

1. Some of the Bidders had raised queries in the published Tender Specification. The Clarifications issued by BHEL are furnished below:

SI No.	Reference Clause No.	Existing Provision	Bidder Query	BHEL's clarification
1.	Techno commercial bid Volume- I Book- I Notice Inviting Tender Clause no. 1.0 (v)	Due Date & Time of Offer Submission Due Date: September 29, 2016 Time: 1500 hrs	We request for Extension of Submission Date for one week	Time extension is not envisaged
2.	SL. NO. 13 of Corrigendum 1 dt. 23 Sept 2016  (Technical Conditions of Contract Volume IA Part- I Chapter-XVIII- PAINTING, Clause No. 1.18.1.5 and 1.18.1.11)	A) Cl. 1.18.1.5 -All the exposed metal .....BHEL/ customer official. Clause is applicable. If any parts/surfaces found to be exposed while in custody of the contractor, the same shall be painted as per painting specification.  B) Cl 1.18.1.11 – Each coat (Primer, intermediate, finish).....arranged by the contractor. (Refer Painting Schedule for Required DFT). Clause is applicable	Please refer SI No. 13(B) of corrigendum 1 dated 23.09.2016 wherein it is clarified "Clause is applicable". Please confirm the area where primer & intermediate paint is to be applied. Also indicate approximate area.  We feel that maximum quantity for each Ref. No. of Rate Schedule should be mentioned (i.e. maximum quantity against 1A, 1B, 1C, 2A & 2B) so that estimated price can be justified and competitive.	No primer/intermediate coat is required in all cases. Clause is applicable only if any parts/surfaces found to be exposed while in the custody of the contractor (i.e., during storage by contractor at site/ Handling at site/After installation of erection components till handing over) the same shall be painted (Primer, intermediate, finish) as per painting specification, for which quantity cannot be ascertained at this stage for obvious reasons.

All other conditions of the Tender Specification remain unchanged. Bidders are requested to consider this Corrigendum as part of the Tender Specification and quote accordingly.

-Sd-  
(Sreenath N G)  
Senior Engineer/ Subcontracts