



**Bharat Heavy Electricals Limited**  
**Material Management Division,**  
**Transmission Business Group,**  
**5<sup>th</sup> Floor, Advant Navis IT Business Park,**  
**Plot No. 7, Sector-142, Expressway Noida, Noida-201305**  
**Distt. Gautam Budh Nagar (U.P.)**  
**Phones: 0120-6748487**  
**Email: bkumawat@bhel.in**

**Subject- Corrigendum-3 TO NIT No.36714**

**DATE :12.03.2018**

1. Project : UJVNL 2x60MW VYASI HYDRO ELECTRIC PROJECT(HEP)
2. Equipment / Item : 220kV GIS
3. Enquiry No. / Date : 277E319 , Dtd. 22/01/2018, Extended Due Date 13.03.2018

With reference to the above tenders, kindly note the following and submit with tender;

- (1) Technical Clarification on corrigendum-2.
- (2) Due date of tender submission date has been extended from **13.03.2018** to **27.03.2018 upto 2.00 PM.**

Opening of the tender shall be at 2:30 PM on same day.

All other terms and conditions of tender shall remain same.

  
18/3/18  
**Bhagchand Kumawat**  
**Mgr (TBMM)**

**Annexure to Corrigendum-3 dated 12.03.2018**

**Clarification on corrigendum -2**

| Sr. No | Pg. no./Cl.No                         | Item               | Description                                                | Corrigendum/clarifications                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         |
|--------|---------------------------------------|--------------------|------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 2.     | Item No. A9 of BOQ of Section-1 of TS | SF6 to Oil Bushing | As per BOQ of Section-1 of Tender technical specification. | <p><b>Clarification:</b> - As per BOQ of Section-1 of Tender technical specification.</p> <p>Bidder to note that connection interface (Connectors of both ends i.e. Transformer Bushing &amp; GIS bushing &amp; interconnector) between GIS and Transformer HV Bushing will in GIS manufacturer scope which also include hardware like Screws, washers, nuts etc.</p> <p>Transformer Bushing will be supplied by BHEL.</p> <p>Required inputs from transformer manufacturer will be furnished during details engineering however tentative OGA, 245kV 1250 AMP (300CT) H.V. Bushing ASSY. is attached for tender purpose only.</p> |

Point 2 of Note of Page no.3 of 3 Corrigendum Dated 28.02.2018

“All other technical parameters of Technical Specification of 220kV GIS, Doc. No. TB-375-316-001 shall remain unchanged.”

In above point Doc. No. TB-375-316-001 is not part of this tender. It should be read as **TB-398-316-101 Rev00** which is Original Tender Technical specification for supply of 220kV GIS for Vyasi HEP.