



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-3-Jan-20

CORRIGENDUM- 03

PROJECT	:	1X660 MW BHUSAWAL TPP UNIT 6
PACKAGE	:	MISC. TANKS(SITE FABRICATED)
ENQUIRY NO	:	E-6345/2019 Dated. 13.12.2019
SUBJECT	:	PRE-BID CLARIFICATION + DUE DATE EXTENSION

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☒

In reference to the above mentioned tender enquiry for **MISC. TANKS(SITE FABRICATED)** package.

Please note the following:

- 1. Both ERW & Seamless pipes are acceptable for sizes above than 50 NB.**
- 2. Due date for offer submission has been extended till 13/01/2020 (2:00 pm) and P1 is to be opened at 3:00 pm on 13/01/2020.**

All the other terms and conditions of the tender enquiry shall remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Guru Das
Dy. Manager