

परियोजना
इंजीनियरिंग
प्रबंधन
Project Engineering
Management

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
(भारत सरकार का उपक्रम)
Bharat Heavy Electricals Limited
(A Govt. of India Undertaking)



CORRIGENDUM-II

Ref: PE-LPE/266 Dtd.17/05/2017

Date: 20/05/2017

**SUBJECT: Open tender Enquiry for Procurement of 10 Nos Split ACs (2 Ton, 5 star Rating)-
Modified commercial terms**

To,

Dear Sir/Madam,

This has reference to our Tender Enquiry no. PE-LPE/266 Dtd.17/05/2017 for the subject package. In this connection, please note that Corrigendum-II is being issued for following, which will be part of NIT: -

Following is to be part of tender enquiry for the subject package: -

- Prices shall be net F.O.R. destination (PEM office) inclusive of freight, handling and packing charges.
- Price format Annexure-A Rev-01 has been modified and attached which shall replace the earlier price format Annexure-A.

All other terms remains unaltered.

Thanking you.
Yours faithfully,
For and on behalf of BHEL


(Kunal Gandhi)
Sr. Engineer/ CMM



कृपया प्रेषित करें :	Please reply to :	फोन Phone No:
बीएचईएल, पीएस-पीइएम	BHEL, PS-PEM,	91-120 - 4368574
पीपीआई भवन	PPEI Building,	Fax No.
प्लॉट नं २५, सेक्टर १६ ए	Plot No.25, Sector 16A,	0120-4329045
नोएडा - २०१ ३०१ उ प्र	Noida-201301 (U.P.)	
भारत	INDIA	

पंजीकृत कार्यालय	Registered Office :
बीएचईएल हाउस	BHEL House,
सीरी फोर्ट	Siri Fort,
नयी दिल्ली - ११० ०४९	New Delhi-110049
भारत	INDIA

Price Format Rev 01 (Supply, Installation and Commissioning of Split ACs in BHEL- PEM Noida)

All prices are in INR

ANNEXURE-A

Sl. No.	Description	Qty	UOM	Rate Per Unit	VAT @%	CST@.....%	Service Tax@.....%	Rate including Taxes	Total Amount F.O.R destination(at PEM Office) including Taxes, freight charges, Handling & Packing charges
A	B	C	D	E	F	G	H	I=[E+F+G+H]	J=[I*C]
1	Supply of Hi-wall Split type Air-Conditioner with following specifications (of Blue Star, Voltas, Hitachi, Mitsubishi, LG or Samsung make) i. Two (02) tonnage capacity with five (05) star rating ii. Cooling capacity 24000 Btu/hr (minimum) iii. High wall type Indoor with Cordless remote controller iv. Out door Unit with hermitically sealed reciprocating/rotary compressor with 05 year warranty v. Filters should be removable and washable polypropylene vi. Units must have functions like programmable timer, Sleep mode and Dry mode vii. Stand for hanging the indoor system	10	Nos.						
2	Automatic Voltage Stabilizer of 5 KVA Rating	10	Nos.						
3	Refrigerant Piping of Copper with Thermally Insulated between Indoor Unit (Evaporator) and Outdoor Unit (Condensor)	140	mtr.						
4	MS Outdoor Stand coated with anti-rusting adhesives	10	Nos.						
5	PVC drain pipe with Joints and connectors	140	mtrs						
6	Cable between Indoor and Outdoor Unit	140	mtrs.						
7	Installation, Testing and Commissioning of 2.0 TR AC units with refrigerant gas charged	10	Nos.						
GRAND TOTAL									
Evaluation will be done on the basis of Grand Total amount and order will be placed to the L1 Vendor.									