

	CLIENT – UTTARAKHAND JAL VIDYUT NIGAM LTD. (UJVN Ltd.) PROJECT: 2 X 60 MW VYASI HEP – 220KV GIS SUBSTATION TECHNICAL SPECIFICATION FOR DG EOT CRANE – 10T CAPACITY	TB-398-563-032A
		Date: 22.02.2020
		Page 1 of 1

CORRIGENDUM TO TECHNICAL SPECIFICATION OF EOT CRANE

Following clauses of Technical specification stands revised. All other data remains unchanged and technical specification shall be followed.

Sl. No.	Ref. Clause of Technical Specification	Revised data to be considered by bidders
1.	Sec-4, Cl. No. 9.8 i) – Lifting Hooks Type – Ramshorn shank	Lifting Hook – Plain Shank type with safety latch.