

Corrigendum to TECHNICAL SPECIFICATION PE-TS-435-558-E006

1. CLAUSE NO. 6 OF SECTION-I OF TECHNICAL SPECIFICATION			
SR. NO.	Type of Luminaire	TECHNICAL SPECIFICATION REQUIREMENT	REVISED REQUIREMENT (AMENDMENT)
11	SF66 (LED)	LED, Flood Light, weather proof, cast aluminium body, protection class IP65, approx. 250W. Fixtures suitable to meet the Flood light requirement, comparable to SF66	LED, Flood Light, weather proof, cast aluminium body, protection class IP65, approx. 400 W. Fixtures suitable to meet the Flood light requirement, comparable to SF66
19	MW96	1 x 125 Mercury, well glass, flame proof increased safety luminaire with vitreous enamelled reflector and cast aluminium alloy LM6 housing for Div. 2 areas	1 x 125 W Mercury well glass, flame proof increased safety luminaire with vitreous enamelled reflector and cast aluminium alloy LM6 housing for Div. 2 areas. gas group IIA/IIB Or LED type flame proof increased safety luminaire (approximately 40 W) which can be integral or retrofit type suitable for Div-2 areas gas group IIA/IIB
20	MW98	1 x 125 Mercury, well glass, flame proof increased safety luminaire with vitreous enamelled reflector and cast aluminium alloy LM6 housing	1 x 125 W Mercury, well glass, explosion proof increased safety luminaire with vitreous enamelled reflector and cast aluminium alloy LM6 housing suitable for Div-2 areas gas group IIC Or LED type explosion proof increased safety luminaire (approximately 40 W) which can be integral or retrofit type suitable for Div-2 areas gas group IIC

2. ANNEXURE-1 OF TECHNICAL SPECIFICATION			
SR. NO.	LOCATION	AVERAGE LUX LEVEL	SPECIFICATION REQUIREMENT
17	Fuel Oil Pump House	150	HPMV , well glass, Flame Proof luminaire*
18	Hydrogen Plant	150	HPMV , well glass, Flame Proof luminaire*
		SPECIFICATIPON REQUIREMENT	REVISED SPECIFICATION REQUIREMENT 9 AMENDMENT)
NOTE		* The fixture will be suitable for Division-2, Group IIA/IIB of hazardous area as per IS-2148.	* The fixture will be suitable for Division-2, Group IIA/IIB/IIC of hazardous area as per IS-2148.

3. ANNEXURE-A OF TECHNICAL SPECIFICATION				
<i>SL.NO.</i>	<i>ITEM DESCRIPTION</i>	<i>VENDOR NAME</i>	<i>ADDRESS AS PER SPECIFICATION</i>	<i>REVISED ADDRESS (AMENDMENT)</i>
9 (1)	LIGHTING FIXTURES (LED)	Neev Luminaries	D-115 , OKHLA INDUSTRIAL AREA, PHASE-1 NEW DELHI – 110020	"B-6/3, Okhla Industrial area, Phase-2, New Delhi".
12 (1)	LIGHTING LAMP (LED)	Neev Luminaries	D-115 , OKHLA INDUSTRIAL AREA, PHASE-1 NEW DELHI – 110020	"B-6/3, Okhla Industrial area, Phase-2, New Delhi".

4. BOQ CUM PRICE SCHEDULE - LIGHTING FIXTURES, LAMPS & MISC ITEMS (Main Supply)

Note in BOQ cum Price schedule:

"Note 10. BIDDER TO QUOTE FOR S.NO. 2.1 IF FIXTURES AT S. NO. 1.19 AND 1.20 AND LAMP AT S.NO. 2.1 ARE SEPARATE. OTHERWISE, COST OF LAMP TO BE INCLUDED IN 1.19 AND 1.20 ONLY."