

TD-106-1 Rev No. 5 Form No.	 HYDERABAD	PRODUCT STANDARD BHEL, HYDERABAD –32. PROJECT ENGINEERING - MECHANICAL				PEMC-07350
						Rev No. 00
						Page 1 of 3
<u>CORRIGENDUM TO</u> <u>TECHNICAL PURCHASE SPECIFICATION</u> <u>FOR</u> <u>SUPPLY OF INERT GAS EXTINGUISHING SYSTEM</u> <u>(PY51297, Rev – 00)</u> PROJECT : 2 X 660 MW ENNORE SEZ SUPERCRITICAL TPS CUSTOMER : TAMILNADU GENERATION AND DISTRIBUTION CORPORATION CONSULTANT : DESEIN PRIVATE LIMITED , NEW DELHI						
Ref. Doc	Revisions : 00 Refer to record of revisions :	Prepared : --SD-- Raviteja J	Checked : --SD-- D V Prashant	Approved : --SD-- P C SEKHAR	Date : 13.07.2018	

COPYRIGHT AND CONFIDENTIAL
 The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED,
 It must not be used directly or indirectly in any way detrimental to the interest of the company.

TD-106-2 Rev No. 5	Form No.	 HYDERABAD	PRODUCT STANDARD BHEL, HYDERABAD –32. PROJECT ENGINEERING – MECHANICAL		PEMC-07350					
					Rev No. 00					
					PAGE 2 of 3					
COPYRIGHT AND CONFIDENTIAL The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED . It must not be used directly or indirectly in any way detrimental to the interest of the company.		The Technical Specification for Supply of Inert Gas Extinguishing System-PY51297-Rev00 stands modified to the extent mentioned under column 'AMENDMENT'. All other details mentioned in the Technical specification shall remain unaltered.								
		<table border="1"> <thead> <tr> <th>Sl. No.</th> <th>Page No. of PY51297-R00</th> <th>Clause no. of PY51297-R00</th> <th>Subject</th> <th>AMENDMENT (Reference clauses shall be read as)</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>18 of 46</td> <td>10.1.iv</td> <td>Design of IGES system</td> <td> The system shall be centralized for all the rooms protected, and shall be designed as total flooding for the single largest room volume (ceiling void + room void + floor void) of control room. The areas to be protected by inert gas extinguishing system shall be divided into the following zones (refer Annexure-10) each: ➤ At El.17.0M - Control Equipment Room-1 (CER-1) - Control Equipment Room-2 (CER-2) - Control Equipment Room-3 (CER-3) - Control Equipment Room-4 (CER-4) - Computer room - Common Control Room (CCR) along with PADO rooms, BMS room, Server/Network room, C&I Engr room, Incharge rooms, Pantry & Dining room. ➤ At El.8.5M - UPS/Charger room </td> </tr> </tbody> </table>	Sl. No.	Page No. of PY51297-R00	Clause no. of PY51297-R00	Subject	AMENDMENT (Reference clauses shall be read as)	1.	18 of 46	10.1.iv
Sl. No.	Page No. of PY51297-R00	Clause no. of PY51297-R00	Subject	AMENDMENT (Reference clauses shall be read as)						
1.	18 of 46	10.1.iv	Design of IGES system	The system shall be centralized for all the rooms protected, and shall be designed as total flooding for the single largest room volume (ceiling void + room void + floor void) of control room. The areas to be protected by inert gas extinguishing system shall be divided into the following zones (refer Annexure-10) each: ➤ At El.17.0M - Control Equipment Room-1 (CER-1) - Control Equipment Room-2 (CER-2) - Control Equipment Room-3 (CER-3) - Control Equipment Room-4 (CER-4) - Computer room - Common Control Room (CCR) along with PADO rooms, BMS room, Server/Network room, C&I Engr room, Incharge rooms, Pantry & Dining room. ➤ At El.8.5M - UPS/Charger room						
Ref. Doc										

TD-106-3 Rev No. 5		Form No.	बी एच ई एल  HYDERABAD PRODUCT STANDARD BHEL, HYDERABAD –32. PROJECT ENGINEERING – MECHANICAL PEMC 07350 Rev No. 00 PAGE 3 of 3				
COPYRIGHT AND CONFIDENTIAL The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED, It must not be used directly or indirectly in any way detrimental to the interest of the company.		RECORD OF REVISIONS					
		Rev. No.	Date	Revision Details	Revised by	Checked by	Approved by
		00	13.07.18	Correction in Technical Specification (PY51297-R00)	Raviteja	D V Prashant	PCS
		Ref. Doc.					