

Ref: BHE/PW/PUR/PDVT-ELE/1187/Corrigendum 01

Date 28/10/2013

To

ALL BIDDERS

**JOB:** FOR HANDLING AT SITE STORES/STORAGE YARD, TRANSPORTATION TO SITE OF WORK, COMPLETE ERECTION, CHECKING OF CALIBRATION, TESTING, COMMISSIONING AND HANDING OVER OF CABLING, TRANSFORMER, DAVR, SOOT BLOWER SYSTEM, VARIABLE FREQUENCY DRIVES FOR ID, FANS, BUS DUCTS, SWITCHGEAR, EARTHING AND ASSOCIATED EQUIPMENTS FOR ELECTRICAL PACKAGE OF 2X250 MW LIGNITE BASED BHAVNAGAR THERMAL POWER PLANT AT BHAVNAGAR ENERGY COMPANY LIMITED DISTRICT- BHAVNAGAR, GUJRAT.

Tender Specification Number: BHE/PW/PUR/PDVT-ELE/1187

Bidders to kindly take note of the following:

**AA) Clarification to the Queries of Bidder**

Sl. No.	Reference clause of tender document	Bidder's query	BHEL's clarification
1.	Vol-II Price Bid SECTION-E1  Sr. No E1.5 and Sr. No. E1.6	Please confirm that same type of cable trays have to be considered for Sl.No. E1.5 & E1.6 as mentioned in BOQ.	Cable trays for E1.5- 300 (W) x120(H) mm Cable trays for E1.6- 150 (W) x120(H) mm
2.	Vol-II Price Bid SECTION-E5E: Sr. No E5E.1 and Sr. No. E5E.2	Please confirm that E5E.1 is 3 Sets of batteries and not Battery chargers.	E5E.1- 450A,220V DC Float Charger Approx.size 1050(L)x480(W)x850(H)mm, weight 5 MT with accessories as describe in tender  E5E.2- 450A,220V DC Float Cum Boost Charger.Approx.size 1050(L)x450(W)x850(H)mm,weight 5 MT with accessories as describe in tender.  It also includes 3 sets of 220 V DC ,1930 AH Capacity,1.85 ECV,108 cells, lead acid plante Hi-discharge battery, with all accessories as described in tender.
3.	Vol-II Price Bid SECTION-E5H Sr. No. E6.12:	Please provide the length of each rod. Also confirm where the no of rods as 14,700 is correct.	Length of each rod is 12 meters.  No. of rods 14700 is correct

Ref: BHE/PW/PUR/PDVT-ELE/1187/Corrigendum 01

Date 28/10/2013

Sl. No.	Reference clause of tender document	Bidder's query	BHEL's clarification
4	TCC, Chapter-II Scope of Works Clause No. 2.9.10 BELOW GROUND EARTHING.	Quantity of Treated earth pits are not shown in BOQ.  Please clarify if the SI No.E6.11 is referring to Treated earth pits.	Quantity of treated earth pits- 55 Nos.  Yes, SI No. E6.11 is referring to Treated earth pits.
5	TCC,Chapter-II Scope of Works Clause No.2.9.15 ISOLATED PHASE BUS DUCT	1) Please clarify whether normal cement or any special cement like Conbextra GPX-2 is to be used for grouting  2) If special cement is to be used, whether BHEL will provide the same.	1) As per drawing.  2) No
6	TCC,Chapter-II Scope of Works Clause No. 2.9.16 :TRANSFORMERS	1) Please clarify whether normal cement or any special cement like Conbextra GPX-2 is to be used for grouting purpose  2) If special cement is to be used, whether BHEL will provide the same.	1) As per Drawing.  2) No
7	Vol-II - Price Bid, Sr. No. E6.12	Whether unit of measurement (UOM) for the item should be Meter or Number. If number, then length of each rod may be specified.	Unit of measurement is in nos only. The standard Length of each rod is 12 Meters
8	Vol-II - Price Bid, Sr. No. E6.13	Kindly confirm the quantity given as 242000 Mtr. is correct or not.	The quantity for referred item no is 2420 Meters
9	Vol-IA - TCC, Cl. No. 2.5, Page 39, Final Painting	Please provide painting scheme and specifications for the scope.	The scheme and specification of paint will be provided at site.

Ref: BHE/PW/PUR/PDVT-ELE/1187/Corrigendum 01

Date 28/10/2013

Sl. No.	Reference clause of tender document	Bidder's query	BHEL's clarification
10	VOL-IA - TCC, Cl. No. 8.1.3, Page 77, VAT (Sales Tax / WCT)	Whether this contract will be considered as a Works Contract and what percentage of WCT is to be deducted from our bills. We have considered this contract as a Labour Oriented Contract and hence WCT will not be applicable, as per our understanding. Please confirm.	WCT is not applicable for subject tender

=====  
All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-01 (Clarification-1187)" against NIT-15349 in BHEL web page ([www.bhel.com](http://www.bhel.com)→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)